

APPENDIX A

**TEST RESULTS OF MOTORS
DURING FIELD TRIALS**

5241-CB14-7121-CWP-1

UNIT 2
IDENTIFICATION Circulating water pump - 1
C.T. RATIO 125/5
P.T. RATIO 1905/68

MOTOR NAME PLATE

SERIAL NO.: SCCWPM00005
RATING 650 hp
FULL LOAD CURRENT 114
SPEED 365 rpm
CONNECTION ---
INSULATION CLASS B
RATED VOLTAGE 3.3 kV
DUTY ---
ENCLOSURE ---
NO OF ROTOR BARS ---
NO. OF STATOR SLOTS ---
POLE 8

1 POWER FACTOR 0.362

2 CURRENT VARIATIONS
PHASE

R	82.0	A
Y	83.8	A
B	81.8	A

CONCLUSION The Current variations are negligible

3 VOLTAGE VARIATIONS
PHASE

R	3286	V
Y	3292	V
B	3288	V

CONCLUSION The Voltage variations are negligible

4 SPEED 371 RPM

5 ROTOR BARS Magnitude

Line Frequency,			
Hz	48.83	0.49	
Slip	0.01		
Slip Frequency,			
Hz	0.52	Hz	
Fault			
frequency,HZ	47.79	Hz	-46.53
	49.87	Hz	-44.91

CONCLUSION The difference in magnitude is more than 45dB, hence no Rotor fault exists

6 LOAD ON MOTOR

Input power, Kw 170
% Loading



7 AIR GAP ECCENTRICITY


CONCLUSION No. of rotor bars data is not given. However no eccentricity pattern was observed.

8 HARMONIC DISTORTION


THD, % 0.30

9 MISALIGNMENT No abnormality has been detected

Current



Voltage



5241-CB18-3311-PCP-7

UNIT 2
IDENTIFICATION Primary coolent pump - 7
C.T. RATIO 200/5
P.T. RATIO 1905/68

OPERATION
RATING

MOTOR NAME PLATE

SERIAL NO.: S-204752-4
RATING 1170 hp
FULL LOAD CURRENT 177
2965
SPEED rpm
CONNECTION ---
INSULATION CLASS F
RATED VOLTAGE 3.3 kV
DUTY ---
ENCLOSURE ---
NO OF ROTOR BARS 51
NO. OF STATOR SLOTS 60
POLE 2

1 POWER FACTOR 0.222

2 CURRENT VARIATIONS
PHASE

R	143.7	A
Y	144.4	A
B	138.6	A

CONCLUSION The Current variations are negligible

3 VOLTAGE VARIATIONS
PHASE

R	3200	V
Y	3195	V
B	3185	V

CONCLUSION The Voltage variations are negligible

4 SPEED 2972 RPM

5 ROTOR BARS Magnitude

Line Frequency,		
Hz	49.29	5.763
Slip	0.01	
Slip Frequency,		
Hz	0.46	Hz
Fault		
frequency,HZ	48.37	Hz -39.75
	50.21	Hz -42.87

CONCLUSION The difference in magnitude is more than 45dB, hence no Rotor fault exists

6 LOAD ON MOTOR

Input power, Kw 175

% Loading

7 AIR GAP ECCENTRICITY


CONCLUSION No eccentricity pattern was observed.

8 HARMONIC DISTORTION


THD, % 0.30

9 MISALIGNMENT No abnormality has been detected

Current



Voltage



5241-CB12-4321-BFP-1

UNIT 2
IDENTIFICATION Boiler feed pump-1
C.T. RATIO 400/5
P.T. RATIO 1905/68

OPERATION
RATING

MOTOR NAME PLATE

1-
SERIAL NO.: 155101
RATING 2500 hp
FULL LOAD CURRENT 375
2960
SPEED rpm
CONNECTION ---
INSULATION CLASS B
RATED VOLTAGE 3.3 kV
DUTY ---
ENCLOSURE ---
NO OF ROTOR BARS ---
NO. OF STATOR SLOTS 60
POLE 2

1 POWER FACTOR 0.227

2 CURRENT VARIATIONS
PHASE

R	308.6	A
Y	312.3	A
B	303.8	A

CONCLUSION The Current variations are negligible

3 VOLTAGE VARIATIONS
PHASE

R	3291	V
Y	3290	V
B	3277	V

CONCLUSION The Voltage variations are negligible

4 SPEED 2978 RPM

5 ROTOR BARS

		Magnitude
Line Frequency,		
Hz	48.98	12.975
Slip	0.01	
Slip Frequency,		
Hz	0.36	Hz
Fault		
frequency,HZ	48.26	Hz -53.32
	49.70	Hz -42.97

CONCLUSION The difference in magnitude is more than 45dB, hence no Rotor fault exists

6 LOAD ON MOTOR

Input power, Kw 399

% Loading

7 AIR GAP ECCENTRICITY


CONCLUSION No. of rotor bar data is not provided. However there is no eccentricity patterns was observed.

8 HARMONIC DISTORTION


THD, % 0.30

9 MISALIGNMENT No abnormality has been detected

Current



Voltage



5241-CB19-3311-PCP-5

UNIT 2
IDENTIFICATION Primary coolent pump - 5
C.T. RATIO 200/5
P.T. RATIO 1905/68

OPERATION
RATING

MOTOR NAME PLATE

SERIAL NO.: S-204752-5
RATING 1170 hp
FULL LOAD CURRENT 177
2965
SPEED rpm
CONNECTION ---
INSULATION CLASS F
RATED VOLTAGE 3.3 kV
DUTY ---
ENCLOSURE ---
NO OF ROTOR BARS 51
NO. OF STATOR SLOTS 60
POLE 2

1 POWER FACTOR 0.232

2 CURRENT VARIATIONS
PHASE

R	141.4	A
Y	139.1	A
B	138.5	A

CONCLUSION The Current variations are negligible

3 VOLTAGE VARIATIONS
PHASE

R	3197	V
Y	3194	V
B	3184	V

CONCLUSION The Voltage variations are negligible

4 SPEED 2976 RPM

5 ROTOR BARS Magnitude

Line Frequency, Hz	49.29	Magnitude	4.59
Slip	0.01		
Slip Frequency, Hz	0.39	Hz	
Fault frequency, HZ	48.50	Hz	-36.03
	50.08	Hz	-38.4

CONCLUSION The difference in magnitude is more than 45dB, hence no Rotor fault exists

6 LOAD ON MOTOR

Input power, Kw	179
% Loading	

7 AIR GAP ECCENTRICITY

CONCLUSION No air gap eccentricity pattern was observed.


8 HARMONIC DISTORTION

THD, % 0.30


9 MISALIGNMENT

No abnormality has been detected

Current



Voltage



5241-CB19-3311-PCP-5

UNIT 2
IDENTIFICATION Process water pump - 1
C.T. RATIO 200/5
P.T. RATIO 1905/68
OPERATION
RATING
MOTOR NAME PLATE
SERIAL NO.: SPM00128
RATING 1200 hp
FULL LOAD CURRENT 188
SPEED 590 rpm
CONNECTION ---
INSULATION CLASS B
RATED VOLTAGE 3.3 kV
DUTY ---
ENCLOSURE ---
NO OF ROTOR BARS ---
NO. OF STATOR SLOTS ---
POLE 10

1 POWER FACTOR 0.206

2 CURRENT VARIATIONS
PHASE

R	167.4	A
Y	167.5	A
B	164.3	A

CONCLUSION The Current variations are negligible

3 VOLTAGE VARIATIONS
PHASE

R	3194	V
Y	3194	V
B	3181	V

CONCLUSION The Voltage variations are negligible

4 SPEED 590 RPM

5 ROTOR BARS Magnitude

Line Frequency,			
Hz	49.29	5.95	
Slip	0.02		
Slip Frequency,			
Hz	0.82	Hz	
Fault			
frequency,HZ	47.65	Hz	-49.14
	50.93	Hz	-50.77

CONCLUSION The difference in magnitude is more than 45dB, hence no Rotor fault exists

6 LOAD ON MOTOR

Input power, Kw	189
% Loading	

7 AIR GAP ECCENTRICITY


CONCLUSION No data given for rotor bars. However no air gap eccentricity pattern was observed.

8 HARMONIC DISTORTION


THD, % 0.30

9 MISALIGNMENT No abnormality has been detected

Current



Voltage



5241-CB21-4321-CEP-1

UNIT 2
Condensate extraction pump -
IDENTIFICATION 1
C.T. RATIO 100/5
P.T. RATIO 1905/68
OPERATION
RATING

MOTOR NAME PLATE

SERIAL NO.: 931567
RATING 525 hp
FULL LOAD CURRENT 80
1480
SPEED rpm
CONNECTION ---
INSULATION CLASS B
RATED VOLTAGE 3.3 kV
DUTY ---
ENCLOSURE ---
NO OF ROTOR BARS ---
NO. OF STATOR SLOTS ---
POLE 4

1 POWER FACTOR 0.194

2 CURRENT VARIATIONS

PHASE
R 66.4 A
Y 67.3 A
B 64.7 A

CONCLUSION The Current variations are negligible

3 VOLTAGE VARIATIONS

PHASE
R 3194 V
Y 3191 V
B 3180 V

CONCLUSION The Voltage variations are negligible

4 SPEED 1483 RPM

5 ROTOR BARS Magnitude

Line Frequency, Hz 49.29 -1.2
Slip 0.01
Slip Frequency, Hz 0.56 Hz
Fault frequency, HZ 48.17 Hz -58.02
50.41 Hz -65.5

CONCLUSION The difference in magnitude is more than 45dB, hence no Rotor fault exists

6 LOAD ON MOTOR

Input power, Kw 71
% Loading

7 AIR GAP ECCENTRICITY


CONCLUSION No data given for rotor bars. However air gap eccentricity pattern was observed.

8 HARMONIC DISTORTION


THD, % 0.30

9 MISALIGNMENT No abnormality has been detected

Current



Voltage



5241-CB22-7121-CWP-2

UNIT 2
IDENTIFICATION Circulating water pump - 2
C.T. RATIO 125/5
P.T. RATIO 1905/68

OPERATION
RATING

MOTOR NAME PLATE

SERIAL NO.: SCCWPM00006
RATING 650 hp
FULL LOAD CURRENT 114
SPEED 365 rpm
CONNECTION ---
INSULATION CLASS B
RATED VOLTAGE 3.3 kV
DUTY ---
ENCLOSURE ---
NO OF ROTOR BARS ---
NO. OF STATOR SLOTS ---
POLE 8

1 POWER FACTOR 0.331

2 CURRENT VARIATIONS

PHASE

R	79.9	A
Y	79.8	A
B	78.4	A

CONCLUSION The Current variations are negligible

3 VOLTAGE VARIATIONS

PHASE

R	3195	V
Y	3189	V
B	3180	V

CONCLUSION The Voltage variations are negligible

4 SPEED 371 RPM

5 ROTOR BARS

		Magnitude
Line Frequency, Hz	49.29	0.816
Slip	0.01	
Slip Frequency, Hz	0.53	Hz
Fault frequency, HZ	48.24	Hz -46.83
	50.34	Hz -45.84

CONCLUSION The difference in magnitude is more than 45dB, hence no Rotor fault exists

6 LOAD ON MOTOR

Input power, Kw 145
% Loading

7 AIR GAP ECCENTRICITY


CONCLUSION No data given for rotor bars. However there is no eccentricity pattern observed.

8 HARMONIC DISTORTION


THD, % 0.30

9 MISALIGNMENT No abnormality has been detected

Current



Voltage



5231-CB15-4321-BFP-7 (LT)

UNIT 2
IDENTIFICATION Boiler feed pump-7
C.T. RATIO 200/1
P.T. RATIO 420/120
OPERATION
RATING
MOTOR NAME PLATE
SERIAL NO.: SPM00103
RATING 125 hp
FULL LOAD CURRENT 157
SPEED 2915
CONNECTION ---
INSULATION CLASS B
RATED VOLTAGE 415 V
DUTY ---
ENCLOSURE ---
NO OF ROTOR BARS ---
NO. OF STATOR SLOTS ---
POLE 2

1 POWER FACTOR 0.939

2 CURRENT VARIATIONS
PHASE

R	129.7	A
Y	131.0	A
B	127.7	A

CONCLUSION The Current variations are negligible

3 VOLTAGE VARIATIONS
PHASE

R	415	V
Y	416	V
B	412	V

CONCLUSION The Voltage variations are negligible

4 SPEED 2981 RPM

5 ROTOR BARS Magnitude

Line Frequency, Hz		
Slip	0.01	
Slip Frequency, Hz	#VALUE!	Hz
Fault frequency, HZ	#VALUE!	Hz
		-40.25
	#VALUE!	Hz
		-36.6

CONCLUSION The difference in magnitude is more than 45dB, hence no Rotor fault exists

6 LOAD ON MOTOR

Input power, Kw	87
% Loading	

7 AIR GAP ECCENTRICITY


CONCLUSION No data is given for rotor nos., however no air gap eccentricity pattern was observed.

8 HARMONIC DISTORTION


THD, % 0.30

9 MISALIGNMENT No abnormality has been detected

Current



Voltage



5231-CB35-3211-PM-1 (LT)

UNIT 2
IDENTIFICATION Moderator coolant pump - 1
C.T. RATIO 225/1
P.T. RATIO 420/120
OPERATION
RATING

MOTOR NAME PLATE

SERIAL NO.: 134-144-01
RATING 150 hp
FULL LOAD CURRENT 196
SPEED 2965
CONNECTION ---
INSULATION CLASS B
RATED VOLTAGE 415 V
DUTY ---
ENCLOSURE ---
NO OF ROTOR BARS ---
NO. OF STATOR SLOTS ---
POLE 2

1 POWER FACTOR 0.800

2 CURRENT VARIATIONS

PHASE

R	187.8	A
Y	210.2	A
B	192.1	A

CONCLUSION The Current variations are negligible

3 VOLTAGE VARIATIONS

PHASE

R	418	V
Y	419	V
B	418	V

CONCLUSION The Voltage variations are negligible

4 SPEED 2986 RPM

5 ROTOR BARS

Magnitude

Line		
Frequency, Hz	50.05	7.14
Slip	0.00	
Slip Frequency, Hz	0.23	Hz
Fault frequency, HZ	49.58	Hz -22.36
	50.52	Hz -28.82

CONCLUSION The difference in magnitude is less than 45dB, hence there may be Rotor fault exists

6 LOAD ON MOTOR

Input power, Kw	114
% Loading	

7 AIR GAP ECCENTRICITY


CONCLUSION No data is given for rotor nos., however no air gap eccentricity pattern was observed.

8 HARMONIC DISTORTION


THD, % 0.30

9 MISALIGNMENT No abnormality has been detected

Current



Voltage



5231-CB33-3211-PM-3 (LT)

UNIT 2
IDENTIFICATION Moderator coolant pump-3
C.T. RATIO 225/1
P.T. RATIO 420/120
OPERATION
RATING
MOTOR NAME PLATE
SERIAL NO.: 340-38-102
RATING 150 hp
FULL LOAD CURRENT 196
SPEED 2965
CONNECTION ---
INSULATION CLASS B
RATED VOLTAGE 415 V
DUTY ---
ENCLOSURE ---
NO OF ROTOR BARS ---
NO. OF STATOR SLOTS ---
POLE 2

1 POWER FACTOR 0.880

2 CURRENT VARIATIONS
PHASE

R	200.9	A
Y	199.9	A
B	201.2	A

CONCLUSION The Current variations are negligible

3 VOLTAGE VARIATIONS
PHASE

R	414	V
Y	417	V
B	413	V

CONCLUSION The Voltage variations are negligible

4 SPEED 2982 RPM

5 ROTOR BARS

		Magnitude
Line Frequency, Hz	49.9	8.68
Slip	0.01	
Slip Frequency, Hz	0.30	Hz
Fault frequency, HZ	49.30	Hz -27.72
	50.50	Hz -37.5

CONCLUSION The difference in magnitude is less than 45dB, hence there may be Rotor fault exists

6 LOAD ON MOTOR

Input power, Kw	127
% Loading	

7 AIR GAP ECCENTRICITY

CONCLUSION

No data is given for rotor nos., however no air gap eccentricity pattern was observed.

8 HARMONIC DISTORTION


THD, %

0.30


9 MISALIGNMENT

No abnormality has been detected

Current



Voltage



5231-CB32-3211-PM-5 (LT)

UNIT 2
IDENTIFICATION Moderator coolant pump -5
C.T. RATIO 225/1
P.T. RATIO 420/120

OPERATION
RATING

MOTOR NAME PLATE

SERIAL NO.: 918874
RATING 150 hp
FULL LOAD CURRENT 196
SPEED 2965
CONNECTION ---
INSULATION CLASS B
RATED VOLTAGE 415 V
DUTY ---
ENCLOSURE ---
NO OF ROTOR BARS ---
NO. OF STATOR SLOTS ---
POLE 2

1 POWER FACTOR 0.850

2 CURRENT VARIATIONS
PHASE

R	215.1	A
Y	224.2	A
B	217.9	A

CONCLUSION The Current variations are negligible

3 VOLTAGE VARIATIONS
PHASE

R	420	V
Y	422	V
B	419	V

CONCLUSION The Voltage variations are negligible

4 SPEED 2977 RPM

5 ROTOR BARS

		Magnitude
Line Frequency, Hz	49.9	9.00
Slip	0.01	
Slip Frequency, Hz	0.38	Hz
Fault frequency, HZ	49.13	Hz -41.5
	50.67	Hz -40.79

CONCLUSION The difference in magnitude is more than 45dB, hence no Rotor fault exists

6 LOAD ON MOTOR

Input power, Kw 136
% Loading

7 AIR GAP ECCENTRICITY

CONCLUSION

No data is given for rotor nos., however no air gap eccentricity pattern was observed.

8 HARMONIC DISTORTION


THD, %

0.30


9 MISALIGNMENT

No abnormality has been detected

Current



Voltage



5231-CB31-3331-PM-3 (LT)

UNIT 2
IDENTIFICATION Auxiliary feed pump - 3
C.T. RATIO 165/1
P.T. RATIO 420/120

OPERATION
RATING

MOTOR NAME PLATE

SERIAL NO.: 78115671-2
RATING 125 hp
FULL LOAD CURRENT 158
SPEED 1475
CONNECTION ---
INSULATION CLASS B
RATED VOLTAGE 415 V
DUTY ---
ENCLOSURE ---
NO OF ROTOR BARS ---
NO. OF STATOR SLOTS ---
POLE 4

1 POWER FACTOR 0.770

2 CURRENT VARIATIONS
PHASE

R	84.8	A
Y	77.9	A
B	86.4	A

CONCLUSION The Current variations are negligible

3 VOLTAGE VARIATIONS
PHASE

R	417	V
Y	420	V
B	417	V

CONCLUSION The Voltage variations are negligible

4 SPEED 1489 RPM

5 ROTOR BARS

		Magnitude
Line Frequency, Hz	49.9	-0.64
Slip	0.01	
Slip Frequency, Hz	0.37	Hz
Fault frequency, HZ	49.17	Hz -52.2
	50.63	Hz -47.12

CONCLUSION The difference in magnitude is more than 45dB, hence no Rotor fault exists

6 LOAD ON MOTOR

Input power, Kw 46
% Loading

7 AIR GAP ECCENTRICITY

CONCLUSION

No data is given for rotor nos., however no air gap eccentricity pattern was observed.

8 HARMONIC DISTORTION


THD, %

0.30


9 MISALIGNMENT

No abnormality has been detected

Current



Voltage



5231-CB36-3331-PM-4 (LT)

UNIT 2
IDENTIFICATION Auxiliary feed pump - 4
C.T. RATIO 165/1
P.T. RATIO 420/120
OPERATION
RATING
MOTOR NAME PLATE
SERIAL NO.: 78115671-1
RATING 125 hp
FULL LOAD CURRENT 158
SPEED 1475
CONNECTION ---
INSULATION CLASS B
RATED VOLTAGE 415 V
DUTY ---
ENCLOSURE ---
NO OF ROTOR BARS ---
NO. OF STATOR SLOTS ---
POLE 4

1 POWER FACTOR 0.865

2 CURRENT VARIATIONS
PHASE

R	85.1	A
Y	91.1	A
B	93.1	A

CONCLUSION The Current variations are negligible

3 VOLTAGE VARIATIONS
PHASE

R	417	V
Y	417	V
B	418	V

CONCLUSION The Voltage variations are negligible

4 SPEED 1486 RPM

5 ROTOR BARS

		Magnitude
Line Frequency, Hz	49.9	0.20
Slip	0.01	
Slip Frequency, Hz	0.47	Hz
Fault frequency, HZ	48.97	Hz -49.16
	50.83	Hz -50.43

CONCLUSION The difference in magnitude is more than 45dB, hence no Rotor fault exists

6 LOAD ON MOTOR

Input power, Kw	56
% Loading	

7 AIR GAP ECCENTRICITY

CONCLUSION No data is given for rotor nos., however no air gap eccentricity pattern was observed.

8 HARMONIC DISTORTION


THD, % 0.30

9 MISALIGNMENT No abnormality has been detected


10 Starting current (Max. Peak) 1916 Amp

11 Starting time 400 msec

Current



Voltage



5241-CB35-7131-PWP-2 (HT)

UNIT 2
IDENTIFICATION Process water pump - 2
C.T. RATIO 200/5
P.T. RATIO 1905/68
OPERATION
RATING

MOTOR NAME PLATE

SERIAL NO.: SPM00129
RATING 1200 hp
FULL LOAD CURRENT 188
SPEED 590
CONNECTION ---
INSULATION CLASS B
RATED VOLTAGE 3.3 kV
DUTY ---
ENCLOSURE ---
NO OF ROTOR BARS ---
NO. OF STATOR SLOTS ---
POLE 10

1 POWER FACTOR 0.869

2 CURRENT VARIATIONS
PHASE

R	156.5	A
Y	152.5	A
B	152.7	A

CONCLUSION The Current variations are negligible

3 VOLTAGE VARIATIONS
PHASE

R	3402	V
Y	3405	V
B	3373	V

CONCLUSION The Voltage variations are negligible

4 SPEED 591 RPM

5 ROTOR BARS

		Magnitude
Line Frequency, Hz	48.68	6.13
Slip	0.02	
Slip Frequency, Hz	0.73	Hz
Fault frequency, HZ	47.22	Hz -48.91
	50.14	Hz -52.14

CONCLUSION The difference in magnitude is more than 45dB, hence no Rotor fault exists

6 LOAD ON MOTOR

Input power, Kw 786
% Loading

7 AIR GAP ECCENTRICITY

CONCLUSION No data is given for rotor nos., however no air gap eccentricity pattern was observed.

8 HARMONIC DISTORTION


THD, % 0.30

9 MISALIGNMENT No abnormality has been detected


10 Starting current (Max. Peak) ----- Amp

11 Starting time 2140 msec

Current



Voltage



5241-CB13-7133-PWPB-1 (HT)

UNIT	2
IDENTIFICATION	Process water booster pump -
C.T. RATIO	1
P.T. RATIO	100/5
OPERATION	1905/68
RATING	
MOTOR NAME PLATE	
SERIAL NO.:	4000/41/102
RATING	450 hp
FULL LOAD CURRENT	70
SPEED	985
CONNECTION	---
INSULATION CLASS	B
RATED VOLTAGE	3.3 kV
DUTY	---
ENCLOSURE	---
NO OF ROTOR BARS	---
NO. OF STATOR SLOTS	---
POLE	6
1 POWER FACTOR	0.853
CURRENT VARIATIONS	
2 PHASE	
	R 47.8 A
	Y 47.7 A
	B 46.3 A
CONCLUSION	The Current variations are negligible
VOLTAGE VARIATIONS	
3 PHASE	
	R 3303 V
	Y 3295 V
	B 3303 V
CONCLUSION	The Voltage variations are negligible
4 SPEED	980 RPM
5 ROTOR BARS	
	Line Frequency, Hz 48.98 Magnitude 72.13
	Slip 0.02
	Slip Frequency, Hz 0.98 Hz
	Fault frequency, HZ 47.02 Hz -2.66
	50.94 Hz 0.982
CONCLUSION	The difference in magnitude is more than 45dB, hence no Rotor faults Exist
6 LOAD ON MOTOR	
	Input power, Kw 230
	% Loading

7 AIR GAP ECCENTRICITY

CONCLUSION No data is given for rotor nos., however no air gap eccentricity pattern was observed.

8 HARMONIC DISTORTION


THD, % 0.30

9 MISALIGNMENT No abnormality has been detected


10 Starting current (Max. Peak) 1012 Amp

11 Starting time 673.1 msec

Current



Voltage



5241-CB26-4321-BFP-6 (HT)

UNIT 2
IDENTIFICATION Boiler feed pump -6
C.T. RATIO 100/5
P.T. RATIO 1905/68

OPERATION

RATING

MOTOR NAME PLATE

SERIAL NO.: SPM00102
RATING 600 hp
FULL LOAD CURRENT 93.5
SPEED 2960
CONNECTION ---
INSULATION CLASS B
RATED VOLTAGE 3.3 kV
DUTY ---
ENCLOSURE ---
NO OF ROTOR BARS ---
NO. OF STATOR SLOTS ---
POLE 2

1 POWER FACTOR 0.869

2 CURRENT VARIATIONS
PHASE

R	37.6	A
Y	36.6	A
B	36.1	A

CONCLUSION The Current variations are negligible

3 VOLTAGE VARIATIONS
PHASE

R	3194	V
Y	3186	V
B	3169	V

CONCLUSION The Voltage variations are negligible

4 SPEED 2972 RPM

5 ROTOR BARS Magnitude

Line Frequency,		
Hz	48.68	-6.67
Slip	0.01	
Slip Frequency,		
Hz	0.45	Hz
Fault		
frequency,HZ	47.77	Hz -61.92
	49.59	Hz -58.87

CONCLUSION The difference in magnitude is more than 45dB, hence no Rotor fault exists

6 LOAD ON MOTOR

Input power, Kw	176
% Loading	

7 AIR GAP ECCENTRICITY

CONCLUSION No data is given for rotor nos., however no air gap eccentricity pattern was observed.

8 HARMONIC DISTORTION


THD, % 0.30

9 MISALIGNMENT No abnormality has been detected


10 Starting current (Max. Peak) 975 Amp

11 Starting time 1525 msec

Current



Voltage



5241-CB26-4321-BFP-6 (HT)

UNIT 2
IDENTIFICATION Boiler feed pump -6
C.T. RATIO 100/5
P.T. RATIO 1905/68

OPERATION
RATING

MOTOR NAME PLATE

SERIAL NO.: SPM00102
RATING 600 hp
FULL LOAD CURRENT 93.5
SPEED 2960
CONNECTION ---
INSULATION CLASS B
RATED VOLTAGE 3.3 kV
DUTY ---
ENCLOSURE ---
NO OF ROTOR BARS ---
NO. OF STATOR SLOTS ---
POLE 2

1 POWER FACTOR 0.869

2 CURRENT VARIATIONS

PHASE

R	37.6	A
Y	36.6	A
B	36.1	A

CONCLUSION The Current variations are negligible

3 VOLTAGE VARIATIONS

PHASE

R	3194	V
Y	3186	V
B	3169	V

CONCLUSION The Voltage variations are negligible

4 SPEED 2972 RPM

5 ROTOR BARS

Magnitude

Line Frequency,			
Hz	48.68		-6.67
Slip	0.01		
Slip Frequency,			
Hz	0.45	Hz	
Fault			
frequency,HZ	47.77	Hz	-61.92
	49.59	Hz	-58.87

CONCLUSION The difference in magnitude is more than 45dB, hence no Rotor fault exists

6 LOAD ON MOTOR

Input power, Kw 176
% Loading

7 AIR GAP ECCENTRICITY

CONCLUSION No data is given for rotor nos., however no air gap eccentricity pattern was observed.

8 HARMONIC DISTORTION


THD, % 0.30

9 MISALIGNMENT No abnormality has been detected


10 Starting current (Max. Peak) 975 Amp

11 Starting time 1525 msec

Current



Voltage



5241-CB40-3331-PM Spare motor

UNIT 2
IDENTIFICATION PM spare motor
C.T. RATIO 250/5
P.T. RATIO 1905/68

OPERATION
RATING

MOTOR NAME PLATE

SERIAL NO.: 400313
RATING 350 hp
FULL LOAD CURRENT 56
SPEED 2975
CONNECTION ---
INSULATION CLASS B
RATED VOLTAGE 3.3 kV
DUTY ---
ENCLOSURE ---
NO OF ROTOR BARS ---
NO. OF STATOR SLOTS ---
POLE 2

1 POWER FACTOR 0.471

2 CURRENT VARIATIONS
PHASE

R	15.9	A
Y	19.0	A
B	16.1	A

CONCLUSION The Current variations are negligible

3 VOLTAGE VARIATIONS
PHASE

R	3180	V
Y	3170	V
B	3154	V

CONCLUSION The Voltage variations are negligible

4 SPEED 2976 RPM

5 ROTOR BARS Magnitude

Line Frequency,			
Hz	48.98	-13.84	
Slip	0.01		
Slip Frequency,			
Hz	0.39	Hz	
Fault			
frequency,HZ	48.20	Hz	-75.91
	49.76	Hz	-71.47

CONCLUSION The difference in magnitude is more than 45dB, hence no Rotor fault exists

6 LOAD ON MOTOR

Input power, Kw	44
% Loading	

7 AIR GAP ECCENTRICITY

CONCLUSION No data is given for rotor nos., however no air gap eccentricity pattern was observed.

8 HARMONIC DISTORTION


THD, % 0.30

9 MISALIGNMENT No abnormality has been detected


10 Starting current (Max. Peak) 906 Amp

11 Starting time 1193 msec

Current



Voltage



5241-CB28-4321-BFP-2

UNIT 2
Boiler feed pump -
IDENTIFICATION 2
C.T. RATIO 400/5
P.T. RATIO 1905/68

OPERATION
RATING

MOTOR NAME PLATE

2-
SERIAL NO.: 155101
RATING 2500 hp
FULL LOAD CURRENT 375
SPEED 2960
CONNECTION ---
INSULATION CLASS B
RATED VOLTAGE 3.3 kV
DUTY ---
ENCLOSURE ----
NO OF ROTOR BARS ---
NO. OF STATOR SLOTS ----
POLE 2

1 POWER FACTOR 0.914

2 CURRENT VARIATIONS
PHASE

R 236.9 A
Y 231.5 A
B 229.0 A

CONCLUSION The Current variations are negligible

3 VOLTAGE VARIATIONS
PHASE

R 3183 V
Y 3172 V
B 3151 V

CONCLUSION The Voltage variations are negligible

4 SPEED 2963 RPM

5 ROTOR BARS Magnitude

Line Frequency, Hz 48.98 10.24
Slip 0.01
Slip Frequency, Hz 0.60 Hz
Fault frequency,HZ 47.77 Hz -51.26
50.19 Hz -50.75

CONCLUSION The difference in magnitude is more than 45dB, hence no Rotor fault exists

6 LOAD ON MOTOR

Input power, Kw 1166
% Loading

7 AIR GAP ECCENTRICITY

CONCLUSION No data is given for rotor nos., however no air gap eccentricity pattern was observed.

8 HARMONIC DISTORTION

THD, % 0.30


9 MISALIGNMENT

No abnormality has been detected

10 Starting current (Max. Peak) 4493 Amp

11 Starting time 3366 msec

Current



Voltage

