

APPENDIX - B

(For Chapter - 6)

INPUT DATA FOR ASSESSMENT OF SECURITY

<u>PLANT - 1</u>			<u>PLANT - 2</u>		
UNIT NO.	REPAIR RATE (1/YR)	FAILURE RATE (1/YR)	UNIT NO.	REPAIR RATE (1/YR)	FAILURE RATE (1/YR)
1	219	4	1	219	4
2	638	4	2	638	4
3	638	2.6	3	638	2.6
4	638	2.6	4	638	2.6
5	638	2.6	5	638	2.6
6	585	2.5	6	585	2.5
7	585	2.5	7	585	2.5
8	151	1.2	8	151	1.2
9	151	1.2	(MTIL = 0.0065)		
10	151	1.2			

(MTIL = 0.0065)

APPENDIX - B

(For Chapter - 6)

INPUT DATA FOR ASSESSMENT OF SECURITY

<u>PLANT - 3</u>			<u>PLANT - 4</u>		
UNIT NO.	REPAIR RATE (1/YR)	FAILURE RATE (1/YR)	UNIT NO.	REPAIR RATE (1/YR)	FAILURE RATE (1/YR)
1	219	4	1	219	4
2	638	4	2	638	4
3	638	2.6	3	638	2.6
4	638	2.6	4	638	2.6
5	638	2.6	5	638	2.6
6	585	2.5	6	585	2.5
(MTIL = 0.00015)			7	585	2.5

(MTIL = 0.00065)

APPENDIX - B

(For Chapter - 6)

INPUT DATA FOR ASSESSMENT OF SECURITY

PLANT - 5		
UNIT NO.	REPAIR RATE (1/YR)	FAILURE RATE (1/YR)
1	219	4
2	638	4
3	638	2.6
4	638	2.6
5	638	2.6
6	585	2.5
7	585	2.5
8	151	1.2
9	151	1.2

(MTIL = 0.00005)