

CHAPTER III

E X P E R I M E N T A L

EXPERIMENTAL(A) General

Samples of standard metals and alloys can be used for carrying out the experiments in different waters and in conditions of differing variables.

For the purpose of present investigation, mild steel has been chosen for assessing the impact of various waters on the extent of corrosion. The mild steel used for the experimental work conformed with the IS-1079, 10 S.W.G. standards. It was taken in the form of sheets manufactured by the steel authority of India Ltd., The chemical composition of the mild steel sample was as follows:

C	.. .	0.09 %
S		0.03 %
Mn		0.31 %
Si		0.03 %
P		Traces
Fe		Remainder

(B) Preparation of Specimen:

A number of rectangular specimen of definite size was cut out from the specified sheet of mild steel, by shearing machine and the edges were ground properly to ensure uniformity. In keeping with the norms prescribed by Protevin (113), edges of the specimen were taken care of. The size and shape of the specimen yielded low edge area ratio and made to have a reasonably large area. The rectangular specimens were pickled in a bath of concentrated HCl containing 20 g/l of Sb_2O_3 and 1 g/l of SnCl_2 to remove any mil-scale adhering the metal surface. They were burnished first lengthwise followed by breadth wise, with IS grit 60, 80, 100, 120, 180 and 240 untill the surface assumed a smooth and even look. They were polished well to free them from pits and scratches and then degreased with acetone by swabbing with cotton. The specimens were weighed accurately.

The following specifications for the mild steel samples were maintained:

Length		5.092 cms
Width		2.954 cms
Thickness		0.300 cms
Diameter of the hole ..		0.400 cms

Shape		Rectangular
Density		7.8 g/cm ³

(C) Waters selected for the study:

Waters from different 'Plants' of the G.S.F.C., Baroda were specially picked up for the study.

- I Cooling water Ammonia Plant
- II Cooling Water Caprolactam Plant
- III Cooling Water Urea Plant
- IV Cooling Water Ammonium Sulphate Plant
- V Makeup Water

All the waters were analysed for the following:

- 1. pH
- 2. Total dissolved solids in p.p.m.
- 3. P.Alkalinity in p.p.m.
- 4. M.Alkalinity in p.p.m.
- 5. Total Alkalinity in p.p.m.
- 6. Total Hardness in p.p.m.
- 7. Calcium Hardness in p.p.m.
- 8. Chloride in p.p.m.
- 9. Phosphate in p.p.m.
- 10. Sulphate in p.p.m.

11. Ammonical Nitrogen in p.p.m.
12. Total Nitrogen in p.p.m.
13. Turbidity in p.p.m.
14. Nitrate in p.p.m.
15. Conductivity in micromhos

The various waters from different 'plants' of the G.S.F.C. (courtsey) were collected and stored for the general study of the impact of the inhibitors, since the waters used, in the plants would vary in their characteristics every day as no standardization of waters before putting them to the use as cooling waters, is normally done. Hence, the 'stored' waters will atleast ensure the identical analysis of waters treated and studied under this investigation. The purpose of a direct comparison and evaluation of the impact of the various inhibitors under identical conditions thus has been well served.

However, the storing capacity, as well as the 'estimate' for 'once storing' being low, after studying three inhibitors, a fresh lot of water was required to be stored. Thus, three different collections of waters from different plants at different time of the year were made over the span of about twenty months. Each collection has been fully analysed. They were designated as:

- C I Benzotriazole
Corobit EPA-529
Aquacid-105 (H.E.D.P.)
- C II Diammonium hydrogen orthophosphate
- CIII Aquacid-105 (H.E.D.P.) + Diammonium hydrogen
orthophosphate

Waters : their analyses are given accordingly.

Table 18

(C) ANALYSIS : COOLING WATER AMMONIA PLANT : I

<u>Characteristics</u>	<u>Results</u>
pH	7.39
Total dissolved solids p.p.m.	827
P. Alkalinity as CaCO_3 p.p.m.	Nil
M. Alkalinity as CaCO_3 p.p.m.	100
Total Alkalinity as CaCO_3 p.p.m.	100
Total Hardness as CaCO_3 p.p.m.	280
Calcium Hardness p.p.m.	110
Chloride as Cl^- p.p.m.	94
Phosphate as PO_4^{3-} p.p.m.	4.1
Sulphate as SO_4^{2-} p.p.m.	640
Ammonical Nitrogen p.p.m.	14
Total Nitrogen p.p.m.	Not analysed
Turbidity p.p.m.	8
Nitrate as NO_3^- p.p.m.	106
Conductivity in micromhos	1445

Table 19

(C) ANALYSIS : COOLING WATER CAPROLACTAM PLANT : I

<u>Characteristics</u>	<u>Results</u>
pH	8.07
Total dissolved solids p.p.m.	1140
P. Alkalinity as CaCO_3 p.p.m.	Nil
M. Alkalinity as CaCO_3 p.p.m.	150
Total Alkalinity as CaCO_3 p.p.m.	150
Total Hardness as CaCO_3 p.p.m.	920
Calcium Hardness p.p.m.	450
Chloride as Cl^- p.p.m.	190
Phosphate as PO_4^{3-} p.p.m.	62
Sulphate as SO_4^{2-} p.p.m.	238
Ammonical Nitrogen p.p.m.	8
Total Nitrogen p.p.m.	Not analysed
Turbidity p.p.m.	23
Nitrate as NO_3^- p.p.m.	Not analysed
Conductivity micromhos	1445

Table 20

(C) ANALYSIS : COOLING WATER UREA PLANT : I

<u>Characteristics</u>	<u>Results</u>
pH	7.55
Total dissolved solids p.p.m.	1760
P. Alkalinity as CaCO_3 p.p.m.	Nil
M. Alkalinity as CaCO_3 p.p.m.	92
Total Alkalinity as CaCO_3 p.p.m.	92
Total Hardness as CaCO_3 p.p.m.	492
Calcium Hardness p.p.m.	228
Chloride as Cl^- p.p.m.	121
Phosphate as $\text{PO}_4^{'''}$ p.p.m.	7
Sulphate as $\text{SO}_4^{''}$ p.p.m.	490
Ammonical Nitrogen p.p.m.	56
Total Nitrogen p.p.m.	127
Turbidity p.p.m.	230
Nitrate as $\text{NO}_3^{'}$ p.p.m.	221
Conductivity micromhos	2248

Table 21

(c) ANALYSIS : COOLING WATER AMMONIUM SULPHATE PLANT: I

<u>Characteristics</u>	<u>Results</u>
pH	7.23
Total dissolved solids p.p.m.	746
P. Alkalinity as CaCO_3 p.p.m.	Nil
M. Alkalinity as CaCO_3 p.p.m.	24
Total Alkalinity as CaCO_3 p.p.m.	24
Total Hardness as CaCO_3 p.p.m.	170
Calcium Hardness as p.p.m.	88
Chloride as Cl^- p.p.m.	43
Phosphate as $\text{PO}_4^{'''}$ p.p.m.	1
Sulphate as $\text{SO}_4^{''}$ p.p.m.	190
Ammonical Nitrogen p.p.m.	25
Total Nitrogen p.p.m.	Not analysed
Turbidity p.p.m.	13
Nitrate as $\text{NO}_3^{'}$ p.p.m.	182
Conductivity micromhos	964

Table 22

(C) ANALYSIS : MAKEUP WATER : I

<u>Characteristics</u>	<u>Results</u>
pH	7.7
Total dissolved solids p.p.m.	372
P.Alkalinity as CaCO_3 p.p.m.	Nil
M. Alkalinity as CaCO_3 p.p.m.	212
Total Alkalinity as CaCO_3 p.p.m.	212
Total Hardness as CaCO_3 p.p.m.	152
Calcium Hardness p.p.m.	64
Chloride as Cl^- p.p.m.	41
Phosphate as $\text{PO}_4^{'''}$ p.p.m.	Traces
Sulphate as $\text{SO}_4^{''}$ p.p.m.	Traces
Ammonical Nitrogen p.p.m.	14
Total Nitrogen p.p.m.	Not analysed
Turbidity p.p.m.	10
Nitrate as $\text{NO}_3^{'}$ p.p.m.	Traces
Conductivity micromhos	458

Table 23

(C) ANALYSIS : COOLING WATER AMMONIA PLANT : II

<u>Characteristics</u>	<u>Results</u>
pH	7.07
Total dissolved solids p.p.m.	602
P. Alkalinity as CaCO_3 p.p.m.	Nil
M. Alkalinity as CaCO_3 p.p.m.	68
Total Alkalinity as CaCO_3 p.p.m.	68
Total Hardness as CaCO_3 p.p.m.	208
Calcium Hardness p.p.m.	84
Chloride as Cl^- p.p.m.	86
Phosphate as $\text{PO}_4^{'''}$ p.p.m.	5
Sulphate as $\text{SO}_4^{''}$ p.p.m.	108
Ammonical Nitrogen p.p.m.	6
Total Nitrogen p.p.m.	Not analysed
Turbidity p.p.m.	6
Nitrate as $\text{NO}_3^{'}$ p.p.m.	Not analysed
Conductivity micromhos	1050

Table 24

(C) ANALYSIS : COOLING WATER CAPROLACTAM PLANT : II

<u>Characteristics</u>	<u>Results</u>
pH	6.96
Total dissolved solids p.p.m.	1234
P. Alkalinity as CaCO_3 p.p.m.	Nil
M. Alkalinity as CaCO_3 p.p.m.	16
Total Alkalinity as CaCO_3 p.p.m.	16
Total Hardness as CaCO_3 p.p.m.	344
Calcium Hardness p.p.m.	160
Chloride as Cl^- p.p.m.	110
Phosphate as PO_4^{3-} p.p.m.	8
Sulphate as SO_4^{2-} p.p.m.	314
Ammonical Nitrogen p.p.m.	Traces
Total Nitrogen p.p.m.	Not analysed
Turbidity p.p.m.	10
Nitrate as NO_3^- p.p.m.	Not analysed
Conductivity micromhos	1490

Table 25

(C) ANALYSIS : COOLING WATER UREA PLANT : II

<u>Characteristics</u>	<u>Results</u>
pH	8.10
Total dissolved solids p.p.m.	1878
P. Alkalinity as CaCO_3 p.p.m.	Nil
M. Alkalinity as CaCO_3 p.p.m.	750
Total Alkalinity as CaCO_3 p.p.m.	750
Total Hardness as CaCO_3 p.p.m.	104
Calcium Hardness p.p.m.	50
Chloride as Cl^- p.p.m.	55
Phosphate as $\text{PO}_4^{'''}$ p.p.m.	1.5
Sulphate as $\text{SO}_4^{''}$ p.p.m.	588
Ammonical Nitrogen p.p.m.	533
Total Nitrogen p.p.m	Not analysed
Turbidity cm^{-1} p.p.m.	964
Nitrate as NO_3^- p.p.m.	Not analysed
Conductivity micromhos	7700

Table 26

(C) ANALYSIS: COOLING WATER AMMONIUM SULPHATE PLANT :II

<u>Characteristics</u>	<u>Results</u>
pH	7.47
Total dissolved solids p.p.m.	448
P. Alkalinity as CaCO_3 p.p.m.	Nil
M. Alkalinity as CaCO_3 p.p.m.	62
Total Alkalinity as CaCO_3 p.p.m.	62
Total Hardness as CaCO_3 p.p.m.	152
Calcium Hardness p.p.m.	60
Chloride as Cl^- p.p.m.	32
Phosphate as PO_4^{3-} p.p.m.	Traces
Sulphate as SO_4^{2-} p.p.m.	86
Ammonical Nitrogen p.p.m.	Traces
Total Nitrogen p.p.m.	Not analysed
Turbidity p.p.m.	Less than 5
Nitrate as NO_3^- p.p.m.	Not analysed
Conductivity micromhos	780

Table 27

(C) ANALYSIS : MAKEUP WATER : II

<u>Characteristics</u>	<u>Results</u>
pH	7.73
Total dissolved solids p.p.m.	268
P. Alkalinity as CaCO_3 p.p.m.	Nil
M. Alkalinity as CaCO_3 p.p.m.	412
Total Alkalinity as CaCO_3 p.p.m.	412
Total Hardness as CaCO_3 p.p.m.	70
Calcium Hardness as CaCO_3 p.p.m.	26
Chloride as Cl^- p.p.m.	40
Phosphate as $\text{PO}_4^{'''}$ p.p.m.	Traces
Sulphate as $\text{SO}_4^{''}$ p.p.m.	6
Ammonical Nitrogen p.p.m.	Traces
Total Nitrogen p.p.m.	Not analysed
Turbidity p.p.m.	9
Nitrate as $\text{NO}_3^{'}$ p.p.m.	Not analysed
Conductivity micromhos	610

Table 28

(C) ANALYSIS : COOLING WATER AMMONIA PLANT : III

<u>Characteristics</u>	<u>Results</u>
pH	7.76
Total dissolved solids p.p.m.	932
P. Alkalinity as CaCO_3 p.p.m.	Nil
M. Alkalinity as CaCO_3 p.p.m.	420
Total Alkalinity as CaCO_3 p.p.m.	420
Total Hardness as CaCO_3 p.p.m.	280
Calcium Hardness p.p.m.	100
Chloride as Cl^- p.p.m.	160
Phosphate as $\text{PO}_4^{'''}$ p.p.m.	2
Sulphate as $\text{SO}_4^{''}$ p.p.m.	56
Ammonical Nitrogen p.p.m.	5
Total Nitrogen p.p.m.	Not analysed
Turbidity p.p.m.	6
Nitrate as $\text{NO}_3^{'}$ p.p.m.	Not analysed
Conductivity micromhos	1000

Table 29

(C) ANALYSIS : COOLING WATER CAPROLACTAM PLANT: III

<u>Characteristics</u>	<u>Results</u>
pH	7.29
Total dissolved solids p.p.m.	1280
P. Alkalinity as CaCO_3 p.p.m.	Nil
M. Alkalinity as CaCO_3 p.p.m.	120
Total Alkalinity as CaCO_3 p.p.m.	120
Total Hardness as CaCO_3 p.p.m.	925
Calcium Hardness p.p.m.	457
Chloride as Cl^- p.p.m.	227
Phosphate as $\text{PO}_4^{'''}$ p.p.m.	66
Sulphate as $\text{SO}_4^{''}$ p.p.m.	246
Ammonical Nitrogen p.p.m.	6
Total Nitrogen p.p.m.	Not analysed
Turbidity p.p.m.	20
Nitrate as NO_3^+ p.p.m.	Not analysed
Conductivity micromhos	2000

Table 30

(C) ANALYSIS : COOLING WATER UREA PLANT : III

<u>Characteristics</u>	<u>Results</u>
pH	6.70
Total dissolved solids p.p.m.	1274
P. Alkalinity as CaCO_3 p.p.m.	Nil
M. Alkalinity as CaCO_3 p.p.m.	90
Total Alkalinity as CaCO_3 p.p.m.	90
Total Hardness as CaCO_3 p.p.m.	390
Calcium Hardness p.p.m.	190
Chloride as Cl^- p.p.m.	200
Phosphate as $\text{PO}_4^{'''}$ p.p.m.	5
Sulphate as $\text{SO}_4^{''}$ p.p.m.	328
Ammonical Nitrogen p.p.m.	17
Total Nitrogen p.p.m.	112
Turbidity p.p.m.	96
Nitrate as $\text{NO}_3^{'}$ p.p.m.	Not analysed
Conductivity micromhos	2300

Table 31

(C) ANALYSIS : COOLING WATER AMMONIUM SULPHATE PLANT :III

<u>Characteristics</u>	<u>Results</u>
pH	8.37
Total dissolved solids p.p.m.	510
P. Alkalinity as CaCO_3 p.p.m.	Nil
M. Alkalinity as CaCO_3 p.p.m.	220
Total Alkalinity as CaCO_3 p.p.m.	220
Total Hardness as CaCO_3 p.p.m.	196
Calcium Hardness p.p.m.	88
Chloride as Cl^- p.p.m.	55
Phosphate as $\text{PO}_4^{'''}$ p.p.m.	1
Sulphate as $\text{SO}_4^{''}$ p.p.m.	18
Ammonical Nitrogen p.p.m.	Traces
Total Nitrogen p.p.m.	Not analysed
Turbidity p.p.m.	Not analysed
Nitrate as $\text{NO}_3^{'}$ p.p.m.	Not analysed
Conductivity micromhos	900

Table 32

(C) ANALYSIS : MAKEUP WATER : III

<u>Characteristics</u>	<u>Results</u>
pH	7.7
Total dissolved solids p.p.m.	372
P. Alkanility as CaCO_3 p.p.m.	Nil
M. Alkalinity as CaCO_3 p.p.m.	212
Total Alkalinity as CaCO_3 p.p.m.	212
Total Hardness as CaCO_3 p.p.m.	152
Calcium Hardness p.p.m.	64
Chloride as Cl^- p.p.m.	41
Phosphate as $\text{PO}_4^{'''}$ p.p.m.	Traces
Sulphate as $\text{SO}_4^{''}$ p.p.m.	Traces
Ammonical Nitrogen p.p.m.	14
Total Nitrogen p.p.m.	Not analysed
Turbidity p.p.m.	10
Nitrate as NO_3^+ p.p.m.	Traces
Conductivity micromhos	458

(D) Inhibitors selected for the study:

- I - Benzotriazole (Gharda Chemicals Private Limited, Dombivali) in concentrations (% Wt/Vol.) of 0.1, 0.2, 0.5, 1 and 2.
- II - Corobit EPA-529 (Ashok Industries, Worli, Bombay-400 018) in concentrations (% Vol/Vol.) of 0.1, 0.2, 0.5, 1, 2 and 5.
- III - Aquacid-105 (H.E.D.P.) (Aquapharm Chemical Co., Pune-411 026) in concentrations (% Vol/Vol) of 0.1, 0.2, 0.5, 1, 2 and 5.
- IV - Diammonium hydrogen orthophosphate GR Grade (Sarabhai M. Chemicals, Baroda) in concentrations (% Wt/Vol) of 0.1, 0.2, 0.5, 1 and 2.
- V - Mixture of Aquacid - 105 (% Vol / Vol).
Diammonium hydrogen orthophosphate (% Wt/Vol.)
in combination of 0.1 + 0.1, 0.1 + 0.5, 0.1 + 1,
5 + 0.1, 5 + 0.5 and 5 + 1.

(E) Procedure:

The weight loss method was employed. The general procedure was the same for all waters taken for study.

The water was taken in a corning glass beaker of 250 ml. capacity. Water was filled up to 2 cms below the brim. Each specimen was suspended 1.0 cm below water level and 1.0 cm above the bottom of beaker maintaining the same depth. The volume of the water for all the experiments was 230 ml. Only one specimen was immersed in each beaker. For blank as well as for concentrations of the waters containing inhibitors, the pH and conductivity were measured first. The condition of experiment was stagnant. Experiments were performed in triplicate, however, only mean values of the results have been recorded. The beakers were kept in a double walled asbestos frame thermostatically controlled cupboard with an automatic arrangement for regulating temperature. Inside the cupboard, the lamps were covered with proper system in order to avoid any effect of light. The temperature was kept at $35^{\circ}\text{C} \pm 1^{\circ}\text{C}$. A few ml of distilled water were added every alternate day to compensate for the losses due to evaporation. On conclusion of experiments, the coupons were removed from the beakers. Simple visual observations with a magnifying glass (X 6) were made. Then they were cleaned mechanically using nylon bristle brush using scouring agent vim. They were then washed with water, immersed in acetone and dried with Rosella brand tissue

paper and weighed. Thus weight loss was determined.

Corrosion rate in mils per year and percentage inhibitor efficiency were calculated.

$$\text{Mils per year (mpy)} = \frac{\text{Weight loss in milligram} \times 534}{A \times D \times T}$$

A = Exposed surface Area (in^2)


D = Density of exposed metal (g/cm^3)

T = Time in hour

$$\% \text{ Inhibitor Efficiency} = \frac{\text{Corrosion rate uninhibited} - \text{Corrosion rate inhibited}}{\text{Corrosion rate uninhibited}} \times 100$$

(F) OBSERVATIONS AND RESULTS

F.I. - BENZOTRIAZOLE

BENZOTRIAZOLE

Formula : $C_6H_5N_3$

Molecular weight	: 119.12
Appearance	: Off white to light yellow powder
Specific gravity (100°C/25°C):	1.19
Assay	: 98.0 % Min.
Moisture	: 0.5 % Max.
Ash	: 0.5 % Max.

Table 33

COOLING WATER AMMONIA PLANT

Material : Mild Steel IS 1079 Quantity of C.W. : 230 ml
 Exposed Surface Area : 6.33 in² Temperature : 35°C ± 1°C
 Density : 7.8 g/cm³ Condition : Stagnant

Inhibitor : Benzotriazole

% inhi- bitor Wt/Vol	Corrosion rate (Mpy)				pH		Conduct- ivity m.mhos		% Inhibitor Efficiency				
	No. of days exposure				Initial After Exposure (No.of days)				No. of days Exposure				
	3	7	15	30	3	7	15	30	3	7	15	30	
Blank	1.41	1.14	1.80	2.77	7.39	8.26	7.62	8.40	8.33	1445	-	-	-
0.1	0.084	0.031	0.023	0.024	7.19	5.50	4.95	6.61	7.24	1365	94.04	97.28	98.72
0.2	0.092	0.030	0.031	0.014	7.03	5.99	5.91	6.90	7.20	1365	93.48	97.37	98.28
0.5	0.078	0.039	0.033	0.018	6.71	5.82	5.67	6.57	6.88	1365	94.47	96.58	98.17
1	0.075	0.043	0.153	0.109	6.52	5.80	5.58	6.43	6.70	1365	94.68	96.23	91.50
2	0.139	0.063	0.015	0.005	6.30	5.69	5.42	6.23	6.52	1365	90.14	94.47	99.17
													99.82

Table 34

COOLING WATER CAPROLACTAM PLANT

Material : Mild Steel IS 1079
 Exposed Surface Area : 6.33 in²
 Density : 7.8 g/cm³
 Quantity of C.W : 230 ml
 Temperature: 35°C ± 1°C
 Condition : Stagnant

Inhibitor : Benzotriazole

% inhi- bitor Wt/Vol	Corrosion rate (Mpy)				pH				Conduct- ivity m.mhos	% Inhibitor Efficiency			
	No. of days exposure				Initial After Exposure (No. of days)					No. of days Exposure			
	3	7	15	30	3	7	15	30		3	7	15	30
Blank	3.61	4.19	3.06	2.76	8.07	8.36	7.94	7.73	7.09	1445	-	-	-
0.1	2.53	2.48	2.30	2.44	7.13	7.59	7.72	7.88	8.07	1445	29.92	40.81	24.84
0.2	2.49	2.39	2.08	1.97	6.91	7.32	7.38	7.52	7.67	1445	31.02	42.96	32.03
0.5	1.73	1.73	1.51	1.25	6.76	6.96	6.97	7.12	7.22	1445	52.08	58.71	50.65
1	1.43	1.35	1.18	0.86	6.67	6.70	6.71	6.81	6.85	1445	60.39	67.78	61.44
2	1.34	1.06	0.81	0.61	6.44	6.50	6.48	6.54	6.60	1445	62.88	74.70	73.52
													77.90

Table 35

COOLING WATER UREA PLANT

Material : Mild Steel IS 1079 Quantity of C.W. : 230 ml
 Exposed Surface Area : 6.33 in² Temperature : 35°C ± 1°C
 Density : 7.8 g/cm³ Condition : Stagnant

Inhibitor : Benzotriazole

% Inhi- bitor Wt./Vol	Corrosion rate (Mpy)				pH				Conducti vity m.mhos	% Inhibitor Efficiency				
	No. of days Exposure				Initial After Exposure (No. of days)					No. of days Exposure				
	3	7	15	30	3	7	15	30		3	7	15	30	
Blank	6.56	4.89	5.35	4.04	7.55	8.37	8.25	8.14	7.12	2248	-	-	-	-
0.1	2.25	2.41	2.45	2.91	7.18	7.56	7.62	7.69	7.68	2248	65.70	50.72	54.21	27.97
0.2	2.32	2.10	2.31	2.22	6.95	7.31	7.39	7.53	7.48	2248	64.63	57.06	56.82	45.05
0.5	1.91	1.74	1.72	1.61	6.73	6.96	7.04	7.30	7.20	2248	70.88	64.42	67.85	60.15
1	1.74	1.50	1.09	1.01	6.47	6.71	6.81	7.02	6.97	2248	73.48	69.33	79.63	75.00
2	1.75	1.28	0.66	0.53	6.30	6.47	6.58	6.76	6.72	2248	73.32	73.82	87.66	86.88

Table 36

COOLING WATER AMMONIUM SULPHATE
PLANT

Material: Mild Steel IS 1079
Exposed Surface Area : 6.33 in²
Density : 7.8 g/cm³
Quantity of C.W : 230 ml
Temperature : 35°C ± 1°C
Condition : Stagnant

Inhibitor : Benzotriazole

% Inhi- bitor Wt/Vol.	Corrosion rate (Mpy)				pH				Conduct- ivity m.mhos	% Inhibitor Efficiency				
	No. of days exposure				Initial After Exposure (No. of days)					No. of days (Exposure)				
	3	7	15	30	3	7	15	30		3	7	15	30	
Blank	5.61	4.81	4.41	4.06	7.23	8.17	7.41	8.01	7.55	964	-	-	-	-
0.1	2.00	2.40	1.98	2.13	6.83	6.36	6.25	7.15	7.00	964	64.35	50.10	55.10	47.54
0.2	1.88	1.80	1.53	1.67	6.72	6.17	6.06	6.89	6.68	964	66.49	62.58	65.31	58.87
0.5	1.98	1.71	1.16	1.16	6.17	5.96	5.58	6.62	6.40	964	64.71	64.45	73.70	71.43
1	2.31	2.01	1.10	0.55	6.02	5.82	5.56	6.37	6.10	964	58.82	58.21	75.06	86.45
2	2.04	1.82	1.22	0.61	5.92	5.70	5.45	6.24	5.95	964	63.64	62.16	72.34	84.98

Table 37

MAKEUP WATER

Material : Mild Steel IS 1079
 Exposed Surface Area : 6.33 in²
 Density : 7.8 g/cm³
 Quantity of C.W : 230 ml
 Temperature : 35°C ± 1°C
 Condition : stagnant

Inhibitor : Benzotriazole

% Inhi- bitor Wt/Vol	Corrosion rate (Mpy)				pH				Conduct- ivity m-mhos	% Inhibitor Efficiency				
	No. of days Exposure				Initi- al	After Exposure (No. of days)				No. of days Exposure	%			
	3	7	15	30		3	7	15			30	3	7	15
Blank	5.40	4.04	3.46	3.75	7.70	8.30	8.30	8.40	8.48	458	-	-	-	-
0.1	2.49	1.89	2.87	2.99	7.26	7.82	7.93	7.99	8.29	458	53.89	53.22	17.05	20.27
0.2	2.59	1.98	2.30	2.68	7.22	7.52	7.63	7.78	8.02	458	52.04	50.99	33.53	28.53
0.5	1.60	1.20	1.43	1.48	6.95	7.10	7.20	7.26	7.42	458	70.37	70.30	58.67	60.57
1	1.01	0.60	0.59	0.53	6.87	6.83	6.91	6.97	7.06	458	81.30	85.15	82.95	85.87
2	0.66	0.28	0.18	0.11	6.62	6.63	6.68	6.67	6.83	458	87.78	93.07	94.80	97.07

F- II - COROBIT EPA - 529

COROBIT EPA - 529

High Molecular Weight complex organoamine phosphonate +

Dispersing Agent

Appearance	: Light yellow clear liquid
Specific Gravity	: 1.27
pH	: 10
Organophosphonate	: 25 % Active Content
Sequestering value	: 300 mg of Calcium / gm

COOLING WATER AMMONIA PLANT

Inhibitor : Corobit EPA-529

% Inhibitor Vol./Vol.	Corrosion rate (Mpy)				pH				Conductivity m.mhos	% Inhibitor Efficiency			
	No. of days Exposure				After Exposure (No. of days)					No. of days Exposure			
	3	7	15	30	3	7	15	30		3	7	15	30
Blank	1.41	1.14	1.80	2.77	7.39	8.26	7.62	8.40	8.33	1445	-	-	-
0.1	Nil	0.024	0.034	0.063	7.87	7.81	8.20	8.05	7.91	1767	100	97.89	98.11
0.2	0.084	0.022	0.019	0.010	8.10	8.08	8.29	8.28	8.07	2088	94.04	98.07	98.94
0.5	0.088	0.037	0.017	0.023	8.49	8.71	8.74	8.77	8.84	3332	93.76	96.75	99.06
1	0.070	0.073	0.276	0.011	8.76	8.81	8.73	9.02	9.04	6424	95.04	93.60	84.67
2	0.405	0.401	0.708	0.715	9.07	9.24	9.00	9.09	9.29	8833	71.28	64.82	60.67
5	0.676	1.12	2.390	3.670	9.64	9.78	9.36	8.99	9.45	16863	52.06	1.75	N*

N* - Negative

Table 39

COOLING WATER CAPROLACTAM PLANT

Material : Mild Steel IS 1079 Quantity of C.W. : 230 ml
 Exposed Surface Area : 6.33 in² Temperature : 35°C ± 1°C
 Density : 7.8 g/cm³ Condition : stagnant

Inhibitor : Corobit EPA-529

% Inhi- bitor Vol/Vol	Corrosion rate (Mpy)				Initial				pH				Conduct- ivity m.mhos				% Inhibitor Efficiency No. of days Exposure			
	No. of days Exposure				After Exposure (No. of days)				After Exposure (No. of days)				After Exposure (No. of days)				After Exposure (No. of days)			
	3	7	15	30	3	7	15	30	3	7	15	30	3	7	15	30	3	7	15	30
Blank	3.61	4.19	3.06	2.76	8.07	8.36	7.94	7.73	7.09	1445	-	-	-	-	-	-	-	-	-	-
0.1	0.93	0.78	0.51	0.42	7.53	8.41	8.35	8.48	8.59	1767	74.24	81.38	83.33	84.78						
0.2	1.19	0.81	0.55	0.50	7.54	8.49	8.47	8.52	8.66	1887	67.04	80.67	82.03	81.88						
0.5	3.20	3.31	3.88	3.36	7.99	8.88	8.62	8.87	9.04	3132	11.33	21.00	N*	N*						
1	2.24	1.87	3.70	4.09	8.73	8.80	8.86	9.10	9.12	4818	37.95	55.37	N*	N*						
2	2.33	1.74	2.14	4.25	9.48	9.06	8.92	9.15	9.38	8833	35.46	58.47	30.07	N*						
5	2.26	1.65	3.41	2.66	10.07	9.60	9.30	9.57	9.58	15257	37.40	60.62	N*	3.62						

* Negative

Table 40

COOLING WATER UREA PLANT

Material : Mild Steel IS 1079 Quantity of C.W. : 230 ml
 Exposed Surface Area : 6.33 in² Temperature : 35°C ± 1°C
 Density : 7.8 g/cm³ Condition : stagnant

Inhibitor : Corobit EPA-529

% Inhi- bitor Vol/Vol	Corrosion rate (Mpy)				pH				Conduc- tivity m.mhos	% Inhibitor Efficiency			
	No. of days Exposure				Initial After exposure (No. of days)					No. of days Exposure			
	3	7	15	30	3	7	15	30	3	7	15	30	
Blank	6.56	4.89	5.35	4.04	7.55	8.37	8.25	8.14	7.12	2248	-	-	-
0.1	1.41	0.92	0.74	0.59	7.43	8.17	8.13	8.03	8.13	2329	78.51	81.19	85.98
0.2	1.74	1.11	0.69	0.54	7.44	8.24	8.23	8.10	8.17	2570	73.48	77.30	87.10
0.5	2.48	2.34	1.04	0.62	7.62	8.42	8.45	8.30	8.43	3854	62.20	52.15	80.56
1	2.05	1.77	3.20	3.84	8.09	8.43	8.53	8.81	8.99	5300	68.75	63.80	40.19
2	1.76	1.37	1.62	3.92	8.62	8.62	8.60	8.93	9.33	8833	73.17	71.98	69.72
5	1.94	1.26	1.40	6.48	9.41	9.17	8.99	8.85	10.15	16060	70.43	74.23	73.83
													N*

* Negative

Table 41

COOLING WATER AMMONIUM SULPHATE PLANT

Material : Mild Steel IS 1079
 Exposed Surface Area : 6.33 in²
 Density : 7.8 g/cm³
 Quantity of C.W. : 230 ml
 Temperature : 35°C ± 1 ° C
 Condition : stagnant

Inhibitor : Corobit EPA-529

% Inhi- bitor Vol/Vol	Corrosion rate (Mpy)				pH				Conduct- ivity m.mhos	% Inhibitor Efficiency						
	No. of days Exposure				Initial	After Exposure (No. of days)				No. of days Exposure						
	3	7	15	30		3	7	15			30	3	7	15	30	
Blank	5.61	4.81	4.41	4.06	7.23	8.17	7.41	8.01	7.55	964	-	-	-	-	-	-
0.1	1.66	1.18	0.81	0.45	7.29	7.96	8.09	8.04	7.52	1365	70.41	75.47	81.63	88.92	88.92	88.92
0.2	2.30	1.22	0.89	0.46	7.37	8.22	8.22	8.25	8.04	1847	59.00	74.64	79.82	88.67	88.67	88.67
0.5	2.79	2.84	2.79	2.63	8.47	8.39	8.67	8.85	8.77	3132	50.27	40.96	36.73	35.22	35.22	35.22
1	2.03	1.62	2.30	2.45	9.08	8.63	8.61	9.05	8.94	4818	63.81	66.32	47.85	39.66	39.66	39.66
2	2.07	1.65	1.72	2.14	9.76	9.14	8.79	8.85	9.22	8030	63.10	65.70	61.00	47.29	47.29	47.29
5	2.37	1.48	1.54	2.55	10.29	9.77	9.34	9.44	9.45	17666	57.75	69.23	65.08	37.19	37.19	37.19

Table 42

MAKEUP WATER

Material : Mild Steel IS 1079
 Exposed Surface Area : 6.33 in²
 Density : 7.8 g/cm³
 Quantity of C.W : 230 ml
 Temperature : 35°C ± 1°C
 Condition : stagnant

Inhibitor : Corobit EPA-529

% Inhi- bitor Vol./Vol.	Corrosion rate (Mpy)					pH		Conduct-% Inhibitor Efficiency	
	No. of days Exposure					Initial After Exposure (No. of days)		ivity m.mhos No. of days Exposure	
	3	7	15	30		3	7	15	30
Blank	5.40	4.04	3.46	3.75	7.70	8.30	8.30	8.40	8.48 458 - -
0.1	2.32	1.65	1.15	2.51	7.78	8.78	8.86	9.04	8.77 843 57.04 59.16 66.76 33.07
0.2	3.50	2.95	4.41	3.28	8.30	8.70	8.77	8.95	8.82 1325 35.19 26.98 N* 12.53
0.5	2.99	2.75	4.53	2.47	9.02	9.11	8.92	9.01	8.89 2529 44.63 31.93 N* 34.13
1	2.63	2.24	2.72	2.28	9.52	9.12	9.10	9.15	9.00 4256 51.30 44.55 21.39 39.20
2	3.28	2.01	2.75	2.93	10.00	9.35	9.02	9.30	9.16 8030 39.26 50.25 20.52 21.87
5	2.45	2.49	2.90	3.85	10.38	9.71	9.26	9.49	9.56 13651 54.63 38.37 16.18 N*

* N - Negative

pH Aquacid - 105 (Blank)	0.33
Density	1.330 g/cm ³ /28.8°C
pH Corobit EPA-529 (Blank)	10.40
Density	1.284 g/cm ³ /28.5°C

BENZOTRIAZOLE

D.M. Water (Blank) pH	6.4
0.1 % Wt/Vol. Benzotriazole	5.5
0.2 % " "	5.42
0.5 % " "	5.36
1 % " "	5.35
2 % " "	5.30

F - III AQUACID - 105 (H. E. D. P.)

AQUACID-105

- | | |
|---|--|
| 1) Name | 1-Hydroxy Ethylidene-
1-1-Diphosphonic acid |
| 2) Abbreviation | HEDP |
| 3) Structure | $ \begin{array}{ccccccc} & \text{OH} & & \text{OH} & & \text{OH} & \\ & & & & & & \\ \text{HO} & - \text{P} & - & \text{C} & - & \text{P} & - \text{OH} \\ & & & & & & \\ & \text{O} & & \text{CH}_3 & & \text{O} & \end{array} $ |
| 4) Mol.Wt. | 206 |
| 5) Commercial Form | Liquid |
| 6) Colour | Colourless to pale yellow |
| 7) Active content | 49 - 51 % |
| 8) Sequestration value
(mg of Ca as CaCO ₃
per gm sequestrant) | 395 - 410 |
| 9) pH (1 % Soln.) | Less than 2 |
| 10) Specific Gravity | 1.33 - 1.37 |
| 11) Solubility | Soluble in water
Phosphoric acid,
ethylene glycol,
most aqueous acids
and bases |
| 12) Chlorine stability | Contains no Nitrogen |

Table 43

COOLING WATER AMMONIA PLANT

Material : Mild Steel IS 1079 Quantity of C.W : 230 ml
 Exposed Surface Area : 6.33 in² Temperature : 35°C ± 1°C
 Density : 7.8 g/cm³ Condition : stagnant
 Inhibitor : Aquacid-105 (H.E.D.P.)

% Inhi- bitor Vol./Vol.	Corrosion rate (Mpy)						pH		Conduc % Inhibitor Efficiency					
							Initial After Exposure		-tivity					
	No. of days Exposure						(No. of days)		No. of days Exposure					
	3	7	15	30	30	30	3	7	15	30	3	7	15	30
Blank	1.41	1.14	1.80	2.77	7.39	7.39	8.26	7.62	8.40	8.33	1445	-	-	-
0.1	9.18	3.97	2.34	1.68	2.74	2.74	5.20	5.92	6.98	7.36	1927	N*	N*	39.35
0.2	14.42	7.41	4.10	2.21	2.20	2.20	4.06	4.68	5.57	6.09	2489	N*	N*	20.22
0.5	38.55	19.03	10.23	5.54	1.83	1.83	3.39	3.56	5.24	5.53	4818	N*	N*	N*
1	74.79	36.92	14.32	7.86	1.63	1.63	3.22	3.16	4.65	2.75	8432	N*	N*	N*
2	149 .09	70.17	24.39	13.01	1.42	1.42	2.81	2.70	3.43	2.18	13250	N*	N*	N*
5	281.35	109.90	65.32	24.58	1.18	1.18	2.18	1.72	2.35	2.04	24090	N*	N*	N*

N* - Negative

Table 44

COOLING WATER CAPROLACTAM PLANT

Material : Mild Steel IS 1079 Quantity of C.W. : 230 ml
 Exposed Surface Area : 6.33 in² Temperature : 35°C ± 1°C
 Density : 7.8 g/cm³ Condition : Stagnant

Inhibitor : Aquacid-105 (H.E.D.P.)

% Inhi- bitor Vol/Vol	Corrosion rate (Mpy)				pH				Conduc tivity in m.mhos	% Inhibitor Efficiency No. of days Exposure			
	No. of days Exposure				Initial After Exposure (No. of days)								
	3	7	15	30	3	7	15	30		3	7	15	30
Blank	3.61	4.19	3.06	2.76	8.07	8.36	7.94	7.73	7.09	1445	-	-	-
0.1	10.08	8.01	5.23	3.62	2.52	4.94	6.51	6.89	7.28	2811	N*	N*	N*
0.2	17.23	10.37	5.46	3.78	2.41	4.78	5.35	5.56	6.23	3573	N*	N*	N*
0.5	40.70	21.56	11.43	6.18	2.15	3.67	4.74	5.26	4.84	7629	N*	N*	N*
1	76.17	39.37	20.02	10.50	1.97	3.22	3.76	4.53	4.63	10841	N*	N*	N*
2	146.97	73.53	37.65	19.61	1.83	3.09	3.49	3.72	3.86	15659	N*	N*	N*
5	273.64	103.69	51.11	29.72	1.66	2.61	2.70	2.55	2.45	32522	N*	N*	N*

N* - Negative

Table 45

COOLING WATER UREA PLANT

Material : Mild Steel IS 1079 Quantity of C.W. : 230 ml
 Exposed Surface Area : 6.33 in² Temperature : 35°C ± 1°C
 Density : 7.8 g/cm³ Condition : stagnant

Inhibitor : Aquacid-105 (H.E.D.P.)

% Inhi- bitor Vol./Vol.	Corrosion rate (Mpy)				pH				Conducti- vity in m.mhos	% Inhibitor Efficiency				
	No. of days Exposure				Initial After Exposure (No. of days)					No. of days Exposure				
	3	7	15	30	3	7	15	30		3	7	15	30	
Blank	6.56	4.89	5.35	4.04	7.55	8.37	8.25	8.14	7.12	2248	-	-	-	-
0.1	8.41	3.30	1.85	0.87	2.28	4.97	5.53	6.37	6.69	3553	N*	32.52	65.42	78.47
0.2	17.11	8.45	4.66	2.97	2.14	4.68	6.05	6.76	7.20	4015	N*	N*	12.90	26.49
0.5	36.24	19.53	9.94	5.66	1.70	3.40	4.65	5.68	6.29	8030	N*	N*	N*	N*
1	69.94	38.46	18.77	10.17	1.45	3.29	4.01	4.68	5.15	12045	N*	N*	N*	N*
2	127.23	37.91	25.84	14.04	1.32	2.86	3.04	2.73	2.73	16863	N*	N*	N*	N*
5	244.24	105.53	48.60	23.42	1.09	2.39	2.35	2.62	2.47	32120	N*	N*	N*	N*

N* - Negative

Table 46

COOLING WATER AMMONIUM SULPHATE PLANT

Material : Mild Steel IS 1079
 Exposed Surface Area : 6.33 in²
 Density : 7.8 g/cm³
 Quantity of C.W. : 230 ml
 Temperature : 35°C ± 1°C
 Condition : stagnant
 Inhibitor : Aquacid-105 (H.E.D.P.)

% Inhi- bitor Vol/Vol,	Corrosion rate (Mpy)				pH				Conduct- % Inhibitor Efficiency				
	No. of days Exposure				Initial After Exposure (No. of days)				ivity in No.of days Exposure m.mhos				
	3	7	15	30	3	7	15	30	3	7	15	30	
Blank	5.61	4.81	4.41	4.06	7.23	8.17	7.41	8.01	7.55	964	-	-	-
0.1	10.95	7.36	5.60	4.05	2.29	4.90	6.13	6.96	7.41	2570	N*	N*	- 0.25
0.2	19.85	10.09	5.64	4.18	2.12	4.03	5.16	6.04	7.05	3614	N*	N*	N*
0.5	44.43	21.97	11.18	6.15	1.85	3.59	4.31	4.74	5.13	6826	N*	N*	N*
1	81.66	51.81	20.29	10.45	1.59	3.57	3.57	4.17	4.88	11242	N*	N*	N*
2	158.02	77.54	37.45	19.74	1.42	3.33	3.39	3.43	4.13	17666	N*	N*	N*
5	251.17	108.85	51.33	25.34	1.20	2.67	2.50	1.97	2.20	32923	N*	N*	N*

N* - Negative

Table 47

MAKEUP WATER

Material : Mild Steel IS 1079
 Exposed Surface Area : 6.33 in²
 Density : 7.8 g /cm³
 Quantity of C.W. : 230 ml
 Temperature : 35°C ± 1°C
 Condition : stagnant
 Inhibitor : Aquacid-105 (H.E.D.P.)

% Inhi- bitor Vol./Vol.	Corrosion rate (Mpy)				pH				Conduct- % Inhibitor Efficiency ivity in No. of days Exposure m.mhos			
	No. of days Exposure				Initial After Exposure (No. of days)							
	3	7	15	30	3	7	15	30	3	7	15	30
Blank	5.40	4.04	3.46	3.75	7.70	8.30	8.30	8.48	458	-	-	-
0.1	7.04	3.91	1.83	1.20	2.59	5.44	5.40	5.70	964	N*	3.22	47.11
0.2	17.12	9.49	5.54	4.22	2.41	5.38	5.88	6.49	3011	N*	N*	N*
0.5	43.98	21.62	10.66	5.61	2.19	4.19	4.60	4.85	6023	N*	N*	N*
1	84.45	38.27	19.92	10.64	2.01	3.56	3.89	4.27	9636	N*	N*	N*
2	158.97	72.50	37.60	20.13	1.83	3.34	3.47	3.73	16060	N*	N*	N*
5	248.61	85.92	49.70	22.75	1.70	2.76	2.67	2.20	27302	N*	N*	N*

N* - Negative

F-IV DI AMMONIUM HYDROGEN ORTHOPHOSPHATE (DAP)



DI AMMONIUM HYDROGEN ORTHOPHOSPHATE

Formula	$(\text{NH}_4)_2 \text{HPO}_4$
Mol. Wt.	132.06
Make	Sarabhai M. Chemicals
Assay	98.0 - 102.0%
pH on 5 % aqueous soln.	7.9 - 8.2
Insoluble matter	Max. 0.003 %
Chloride Cl^-	Max. 0.0003%
Sulphate SO_4^{--}	Max. 0.002 %
Nitrate (NO_3^-)	Max. 0.001 %
Arsenic (AS)	0.00005 %
Iron (Fe)	Max. 0.0005 %
Heavy Metal as (pb)	Max. 0.0005 %
Potassium (K)	Max. 0.01 %
Sodium (Na)	Max. 0.01 %

Table 48

COOLING WATER AMMONIA PLANT

Material : Mild Steel IS 1079

Exposed Surface Area : 6.33 in²

Density : 7.8 g/cm³

Quantity of C.W. : 230 ml

Temperature : 35°C ± 1°C

Condition : stagnant

Inhibitor : Di ammonium Hydrogen Orthophosphate

% Inhi- bitor Wt./Vol.	Corrosion rate (Mpy)				pH				Conduct- ivity in m.mhos	% Inhibitor Efficiency			
	No. of days Exposure				Initial After Exposure (No. of days)					No. of days Exposure			
	3	7	15	30	3	7	15	30		3	7	15	30
Blank	3.80	3.43	3.25	2.84	7.07	8.08	7.23	7.79	7.52	1050	-	-	-
0.1	0.67	1.22	0.90	1.03	7.81	7.42	7.31	6.70	5.67	2480	82.36	64.43	72.31 63.73
0.2	2.47	2.13	2.27	0.69	7.91	7.57	7.49	6.68	6.19	4000	35.00	37.90	30.15 75.70
0.5	1.35	0.23	0.33	0.13	8.02	7.47	7.38	6.58	6.17	7800	64.47	93.29	89.85 95.42
1	0.18	0.14	0.66	0.25	8.18	7.47	7.38	6.81	6.30	13100	95.26	95.92	79.69 91.19
2	0.23	0.13	0.035	0.030	8.36	7.64	7.40	7.00	6.80	22400	93.95	96.21	98.92 98.94

Table 49

COOLING WATER CAPROLACTAM PLANT

Material : Mild Steel IS 1079

Quantity of C.W. : 230 ml

Exposed Surface Area: 6.33 in²

Temperature : 35°C ± 1°C

Density : 7.8 g/cm³

Condition : stagnant

Inhibitor : Diammonium hydrogen orthophosphate

% Inhi- bitor Wt./Vol.	Corrosion rate (Mpy)				pH				Conduct- ivity in m.mhos	% Inhibitor Efficiency			
	No. of days Exposure				Initial After Exposure (No. of days)					No. of days Exposure			
	3	7	15	30	3	7	15	30		3	7	15	30
Blank	3.74	2.62	5.16	3.97	6.96	8.30	7.37	7.88	7.58	1490	-	-	-
0.1	0.28	0.47	1.24	0.93	7.60	7.58	7.31	6.46	6.14	2700	92.51	82.06	75.97
0.2	2.52	1.73	1.65	1.13	7.86	7.66	7.28	6.09	6.34	4000	32.62	33.97	68.02
0.5	2.40	0.54	1.04	0.37	8.17	7.52	7.44	6.19	5.99	7700	35.83	79.39	79.84
1	0.18	0.077	0.20	*0.007	8.34	7.61	7.45	6.35	5.99	12600	95.19	97.06	96.12
2	0.20	0.081	0.28	*0.008	8.52	7.52	7.48	6.87	6.02	21500	94.65	96.91	94.57

* % Wt. gain

W* Wt. gain

Table 50

COOLING WATER UREA PLANT

Material : Mild Steel IS 1079
 Exposed Surface Area : 6.33 in²
 Density : 7.8 g/cm³
 Quantity of C.W. : 230 ml
 Temperature : 35°C ± 1°C
 Condition : stagnant
 Inhibitor : Diammonium hydrogen Orthophosphate

% Inhi- bitor Wt/Vol.	Corrosion rate (Mpy)				pH				Conduct- ivity in m.mhos	% Inhibitor Efficiency				
	No. of days Exposure				Initial After Exposure (No. of days)					No. of days Exposure				
	3	7	15	30	3	7	15	30		3	7	15	30	
Blank	0.24	0.14	0.060	0.028	8.10	7.65	6.20	6.45	6.33	7700	-	-	-	-
0.1	0.21	0.071	0.057	0.012	8.12	7.63	7.03	6.36	6.56	8800	12.5	49-29	5.00	57.14
0.2	0.22	0.074	0.043	0.016	8.14	7.68	7.18	6.31	6.47	9900	8.33	47.14	28.33	42.86
0.5	0.17	0.078	0.39	0.018	8.27	7.64	7.28	6.69	6.37	12600	29.17	44.29	N*	35.71
1	0.19	0.087	0.31	0.014	8.41	7.64	7.44	6.82	6.54	17500	20.83	37.86	N*	50.00
2	0.30	0.059	0.31	0.021	8.50	7.67	7.41	6.87	6.74	25600	N*	57.86	N*	25.00

N* - Negative

Table 51

COOLING WATER AMMONIUM SULPHATE PLANT

Material : Mild Steel IS 1079
Exposed Surface Area : 6.33 in²
Density : 7.8 g/cm³

Quantity of C.W : 230 ml
Temperature : 35°C ± 1°C
Condition : stagnant

Inhibitor : Diammonium Hydrogen Orthophosphate

% Inhi- bitor Wt/Vol;	Corrosion rate (Mpy)				pH				Conduct- ivity in m.mhos	% Inhibitor Efficiency			
	No. of days Exposure				After Exposure (No. of days)					No. of days Exposure			
	3	7	15	30	3	7	15	30	3	7	15	30	
Blank	2.96	2.67	2.34	2.33	7.47	8.85	8.41	8.36	8.29	780	-	-	-
0.1	2.02	1.44	1.41	0.90	7.98	8.00	8.04	6.44	6.58	2100	31.76	46.07	39.74
0.2	0.93	0.70	1.03	0.086	8.04	7.83	7.67	6.43	6.19	3700	68.58	73.78	55.98
0.5	0.081	0.11	0.53	0.049	8.31	7.70	7.56	6.79	6.14	7550	97.26	95.88	77.35
1	0.062	0.096	0.31	*0.093	8.39	7.69	7.54	7.05	6.33	12700	97.91	96.40	86.75
2	0.088	0.070	0.12	*0.037	8.51	7.79	7.56	7.22	6.18	22100	97.03	97.38	94.87

* % Wt. gain

W * Wt. gain

Table 52

MAKEUP WATER

Material : Mild Steel IS 1079

Quantity of C.W : 230 ml

Exposed Surface Area : 6.33 in².

Temperature : 35°C ± 1°C

Density : 7.8 g/cm³

Condition : stagnant

Inhibitor : Diammonium Hydrogen Orthophosphate

% Inhi- bitor Wt/Vol.	Corrosion rate (Mpy)				pH				Conducti- vity in m.mhos				% Inhibitor Efficiency			
	No. of days Exposure				Initial After Exposure (No. of days)				No. of days Exposure				No. of days Exposure			
	3	7	15	30	3	7	15	30	3	7	15	30	3	7	15	30
Blank	3.15	2.63	1.58	1.72	7.73	8.87	8.73	8.38	8.58	610	-	-	-	-	-	-
0.1	2.68	2.42	1.50	1.09	7.98	8.12	7.50	6.96	6.33	2050	14.92	7.98	5.06	36.63		
0.2	1.56	0.61	0.95	0.41	8.02	7.84	7.49	6.59	6.25	3500	50.48	76.81	39.87	76.16		
0.5	0.43	0.17	0.14	0.17	8.18	7.67	7.47	7.31	6.14	7450	86.35	93.54	91.14	90.12		
1	0.095	0.097	0.041	0.22	8.32	7.67	7.43	7.23	6.69	12600	96.98	96.31	97.41	87.21		
2	0.15	0.12	0.34	0.024	8.46	7.62	7.46	7.21	7.03	22000	95.24	95.44	97.85	98.60		

F - V AQUACID-105 + DAP

Table 53

COOLING WATER AMMONIA PLANT

Material : Mild Steel IS 1079

Quantity of C.W : 230 ml

Exposed Surface Area : 6.33 in²

Temperature : 35°C ± 1°C

Density : 7.8 g/cm³

Condition : stagnant

Inhibitor : Aquacid-105 (H.E.D.P.) +
Diammonium hydrogen orthophosphate

% Inhi- bitor %W/V Aq. +W/V DAP.	Corrosion rate (Mpy)				pH				Conduct- ivity in m.mhos	% Inhibitor Efficiency			
	No. of days Exposure				Initial After Exposure (No. of days)					No. of days Exposure			
	3	7	15	30	3	7	15	30		3	7	15	30
Blank	3.26	3.37	1.89	2.62	7.76	8.79	8.88	7.69	6.98	1000	-	-	-
0.1+0.1	8.27	3.08	1.67	1.18	6.31	7.19	7.07	6.48	6.09	2250	N*	8.61	11.64
0.1+0.5	5.39	3.07	1.52	0.90	7.29	7.37	7.05	6.27	5.99	7400	N*	8.90	30.16
0.1+1	7.24	3.73	1.70	1.09	7.64	7.46	7.17	6.68	6.16	12500	N*	N*	10.05
5+0.1	206.25	109.11	32.32	26.19	1.28	2.13	2.10	2.13	2.31	26100	N*	N*	N*
5+0.5	150.12	99.36	41.27	33.46	1.44	2.39	2.23	2.39	3.26	22700	N*	N*	N*
5+1.0	173.05	86.70	35.55	22.05	1.68	2.59	2.48	2.61	2.89	20700	N*	N*	N*

N* - Negative

Table 54

COOLING WATER CAPROLACTAM PLANT

Material : Mild Steel IS 1079
 Exposed Surface Area : 6.33 in²
 Density : 7.8 g/cm³
 Quantity of C.W. : 230 ml
 Temperature : 35°C ± 1°C
 Condition : stagnant

Inhibitor : Aquacid-105 (H.E.D.P.) +
 Diammonium hydrogen orthophosphate

% Inhi bitor %V/V Aq.+ %W/V DAP	Corrosion rate (Mpy)				pH				Conduct- % Inhibitor Efficiency ivity in No. of days Exposure m.mhos				
	Initial				After Exposure (No. of days)								
	3	7	15	30	3	7	15	30	3	7	15	30	
Blank	6.69	5.17	3.66	3.23	7.29	8.43	8.50	7.12	8.54	2000	-	-	-
0.1+0.1	6.17	2.73	1.31	0.58	5.90	6.70	6.83	6.70	6.93	3000	7.77	47.20	64.21 82.04
0.1+0.5	8.21	2.08	1.08	0.48	7.12	7.31	6.90	6.86	6.75	7900	N*	59.77	70.49 85.14
0.1+1	11.35	4.18	1.12	1.09	7.52	7.38	7.09	6.88	6.74	13500	N*	19.15	69.40 66.25
5+0.1	189.71	111.43	52.66	20.25	1.25	2.30	2.11	2.20	2.25	27500	N*	N*	N* N*
5+0.5	204.42	81.48	51.27	23.40	1.38	2.57	2.27	2.35	2.62	24000	N*	N*	N* N*
5 + 1	221.38	85.90	50.89	27.15	1.65	2.66	2.48	2.64	3.21	22000	N*	N*	N* N*

N* - Negative

Table 55

COOLING WATER UREA PLANT

Material : Mild Steel IS-1079

Quantity of C.W. : 230 ml

Exposed Surface Area : 6.33 in²

Temperature : 35°C ± 1°C

Density : 7.8 g/cm³

Condition : stagnant

Inhibitor: Aquacid-105 (H.E.D.P.) + Diammonium hydrogen Orthophosphate

% Inhi bitor %V/V Aq+ %W/V DAP	Corrosion rate (Mpy)				pH				Conduct % Inhibitor Efficiency			
	No. of days Exposure				Initial After Exposure (No. of days)				-ivity in m.mhos			
	3	7	15	30	3	7	15	30	3	7	15	30
Blank	6.55	1.36	3.27	3.57	6.70	8.37	8.03	8.34	6.82	2300		
0.1+0.1	4.81	1.46	0.81	0.61	5.20	6.32	6.34	6.57	6.46	3600	26.56 N*	75.22 82.91
0.1+0.5	4.89	1.80	0.77	0.65	7.13	7.08	6.85	6.56	5.87	8300	25.34 N*	76.45 81.79
0.1+1	4.19	1.72	1.17	0.59	7.37	7.15	6.69	6.25	6.06	13900	36.03 N*	64.22 83.47
5.0+0.1	196.12	86.74	42.48	29.77	1.35	2.08	2.10	2.08	2.16	25900	N* N*	N* N*
5+0.5	205.11	74.30	46.49	31.44	1.50	2.25	2.26	2.23	2.90	22000	N* N*	N* N*
5+1	175.19	59.81	41.22	26.79	1.70	2.53	2.52	2.45	2.68	20900	N* N*	N* N*

N* - Negative

COOLING WATER AMMONIUM SULPHATE PLANT

Quantity of C.W. : 230 ml

Temperature : $35^{\circ}\text{C} \pm 1^{\circ}\text{C}$

Condition : stagnant

Inhibitor : Aquacid-105 (H.E.D.P.) +
Diammonium hydrogen orthophosphate

% Inhi- bitor	Corrosion rate (Mpy)					pH					Conduct- ivity in m.mhos	% Inhibitor Efficiency				
	No. of days Exposure					Initial After Exposure (No. of days)						No. of days Exposure				
	3	7	15	30	3	7	15	30	3	7		15	30			
Blank	4.94	3.59	2.73	2.24	8.37	8.79	8.16	7.92	7.72	900	-	-	-			
0.1+0.1	7.01	3.38	1.85	1.73	6.62	7.22	7.21	6.66	6.51	2300	N*	5.85	32.23			
0.1+0.5	5.93	4.05	2.66	1.72	7.45	7.46	7.26	6.77	6.43	7900	N*	N*	2.56			
0.1+1	5.90	3.82	3.33	1.78	7.68	7.48	7.13	7.01	6.82	13800	N*	N*	23.21			
5+0.1	168.98	105.86	45.41	22.47	1.36	2.15	2.09	2.12	2.21	29900	N*	N*	N*			
5+0.5	178.17	101.23	49.30	24.58	1.52	2.32	2.23	2.31	2.74	23400	N*	N*	N*			
5+1	171.65	84.38	42.52	21.83	1.80	2.70	2.53	2.54	2.79	21500	N*	N*	N*			

N* - Negative

Table 57

MAKEUP WATER

Material : Mild Steel IS 1079
 Exposed Surface Area : 6.33 in²
 Density : 7.8 g/cm³
 Quantity of C.W : 230 ml
 Temperature : 35° ± 1°C
 Condition : stagnant
 Inhibitor - Aquacid-105 (H.E.D.P.) +
 Diammonium hydrogen orthophosphate

% Inhi- bitor %V/V Aq.+ %W/V DAP.	Corrosion rate (Mpy)				pH				Conduct ivity in m.mhos	% Inhibitor Efficiency			
	No. of days Exposure				Initial After Exposure (No. of days)					No. of days Exposure			
	3	7	15	30	3	7	15	30		3	7	15	30
Blank	5.40	4.04	3.46	3.75	7.70	8.30	8.40	8.48	458	-	-	-	-
0.1+0.1	6.62	2.96	1.91	1.19	6.30	7.08	7.04	7.16	2030	N*	26.73	44.80	68.27
0.1+0.5	7.40	2.24	3.58	1.26	7.10	7.30	6.97	7.10	7500	N*	44.55	N*	66.40
0.1+1	9.01	4.53	1.80	4.69	7.40	7.32	7.16	6.84	13700	N*	N*	47.98	N*
5+0.1	243.83	104.67	49.79	21.28	1.00	2.61	2.48	2.19	29000	N*	N*	N*	N*
5+0.5	215.36	83.58	53.75	24.87	1.20	2.85	2.70	2.38	24900	N*	N*	N*	N*
5+1	225.93	80.72	49.13	31.11	1.45	3.03	2.96	2.61	22400	N*	N*	N*	N*

N* - Negative

(G) EFFECT OF SURFACE TREATMENT ON INHIBITOR
EFFICIENCY WITH 2% Wt./Vol. EBNZOTRIAZOLE

(G) Effect of 2% Wt/Vol Benzotriazole on surface treatment

Here the specifications of specimen, experimental procedure and experimental conditions were the same as those of the previous experiments. But the water used was synthetic cooling water prepared in laboratory. Two sets of different surface finish specimens were taken, one burnished with IS grit 60 only (rough surface) and the other burnished with IS grit 60, 80, 100, 120, 240 (smooth surface). The concentration of Benzotriazole was 2 % Wt/Vol. The pH change measurements, visual observations, corrosion rate calculation and inhibitor efficiency derivations were done after 3, 7, 15 and 30 days.

Composition of Synthetic Cooling Water

pH	9.56
NaHCO ₃	220 mg/l
Na ₂ SO ₄	240 mg/l
NaCl	231 mg/l
NaOH	20 mg/l
CaCO ₃	305 mg/l
Na ₂ SiO ₃	87 mg/l
Conductivity	1600 micromhos

Table 58

SYNTHETIC COOLING WATER

Material : Mild Steel IS 1079
 Exposed Surface Area : 6.33 in²
 Density : 7.8 g/cm³
 Quantity of C.W : 230 ml
 Temperature : 35°C ± 1°C
 Condition : stagnant

Inhibitor : Benzotriazole

Size of Grit	% Wt/Vol of Benzotriazole	Corrosion rate (Mpy)				pH				Conductivity in m.mhos	% Inhibitor Efficiency				
		No. of days Exposure				Initial	After Exposure (No. of days)				No. of days Exposure				
		3	7	15	30		3	7	15						30
60	Blank	4.18	3.71	2.39	2.58	9.56	9.20	9.01	8.91	8.88	1600	-	-	-	-
60	2	1.25	0.75	0.49	0.18	6.76	6.89	7.00	7.11	7.29	1410	70.0	79.78	79.50	93.02
240	Blank	3.37	3.53	3.14	3.00	9.56	9.20	8.89	8.89	8.86	1600	-	-	-	-
240	2	1.16	0.51	0.29	0.16	6.76	6.89	7.00	7.10	7.27	1410	66.00	85.55	90.76	94.67

(H) ANODIC POLARIZATION STUDY

(H) ANODIC POLARIZATION

The experiments have been carried out using Potentiodyne Analyser M-4100.

The test assembly consists of five naked polarization cell with two platinum auxiliary electrodes, mild steel test electrode ($A = 8.53 \text{ Cm}^2$), thermometer pocket, luggin probe for making contact between reference saturated calomel electrode and test electrode. The tip of the luggin probe was kept at 1 mm. distance from test electrode to avoid IR drop. The polarization cell contained 900 ml of the corrodent i.e. water. Steady state potential were measured with the help of philips DC - micro volt meter. As soon as the steady state potential was achieved, the graph was obtained automatically at a speed of 2V/hr. Now with the help of polarization curves of various concentrations of the inhibitor and blank water, shift in potential with respect to blank was recorded.

The polarization potential shift in anodic or cathodic direction with respect to blank water, decides the nature of the inhibitor in terms of anodic or cathodic inhibitor.





FIGURE - 11

STANDARD POLARIZATION CELL (114)
SCHEMATIC DIAGRAM.



- | | |
|--------------------------------------|-----------------------------------|
| 1. VOLTAGE SCALE POSITION CONTROL | 9. PEN LIFT |
| 2. VOLTAGE SCALE SENSITIVITY CONTROL | 10. OPERATE |
| 3. VOLTAGE SWEEP GENERATOR CONTROL | 11. CURRENT SCALE SELECTOR |
| 4. VOLTAGE LIMITS | 12. VOLTAGE SCALE EXPANSION |
| 5. HORIZONTAL AXIS SELECTOR SWITCH | 13. RECORDER COORDINATE CHECK |
| 6. POWER | 14. OFFSET VOLTAGE CONTROL |
| 7. CURRENT POLARITY METER | 15. CURRENT SCALE SENSITIVITY |
| 8. SWEEP DIRECTION COMMAND | 16. CURRENT AXIS POSITION CONTROL |

FIG.12 POTENTIODYNE ANALYZER.

Table 59

(H) I : BENZOTRIAZOLE INHIBITOR

% Concentration Wt/Vol	Shift in potential mv	Direction
0.1	480	Anodic
2	520	Anodic

(H) II : COROBIT EPA - 529

% Concentration Vol/Vol	Shift in potential mv	Direction
0.1	120	Cathodic
5	180	Cathodic

(H) III : AQUACID-105 (H.E.D.P.)

% Concentration Vol/Vol	Shift in potential mv	Direction
0.1	-	Mix.
0.2	160	Anodic
5	260	Anodic

(H) IV : DIAMMONIUM HYDROGEN ORTHOPHOSPHATE (DAP)

% Concentration Wt/Vol	Shift in potential mv	Direction
0.1	40	Cathodic
2	250	Cathodic

(H) V : AQUACID-105 (H.E.D.P.) + DIAMMONIUM HYDROGEN ORTHOPHOSPHATE (DAP).

% Concentration Vol/Vol + Wt/Vol	Shift in potential mv	Direction
0.1 + 0.1	100	Cathodic
0.1 + 0.5	110	Cathodic
0.1 + 1	130	Cathodic
5 + 1	170	Anodic

(I) NON HEAT TRANSFER LOOP METHOD

(I) Non-Heat Transfer Loop Method:

Carefully prepared and weighed metal coupons were installed in contact with flowing cooling water for a measured length of time. After removal from the system, these coupons were examined, cleaned and reweighed. The corrosivity and fouling characteristics of the water were determined from the difference in weight, the depth and distribution of pits, and the weight and characteristics of the foreign matter on the coupons.

Waters investigated by this method were:

- (i) Ammonia Plant Cooling Water
- (ii) Caprolactam Plant Cooling Water

Coupon loop connections were made in inlet, outlet and makeup water bypass line in both the plants. Four coupons were inserted in each loop. The flow velocity in each line was kept 1.5 ft/Sec. The temperature of the inlet, outlet and makeup water varied with seasonal weather conditions.

Temperature °CAmmonia Plant

Inlet $40^{\circ} \pm 1^{\circ}\text{C}$

Outlet $35^{\circ} \pm 1^{\circ}\text{C}$

Makeup Water $31^{\circ} \pm 1^{\circ}\text{C}$

Caprolactam Plant

Inlet $36^{\circ} \pm 1^{\circ}\text{C}$

Outlet $33^{\circ} \pm 1^{\circ}\text{C}$

Makeup Water $31^{\circ} \pm 1^{\circ}\text{C}$

The coupons were cut from single sheet of mild steel conforming to IS 1079 in sizes of 102 mm x 13 mm x 3 mm. A hole of 4 mm size was drilled near upper edge. All sharp edges on the coupons specimen were debured by using emry belt. For the hole, oversize drill was used. The mill scales were removed with inhibited hydrochloric acid containing 20 g/l Sb_2O_3 and 1 g/l SnCl_2 and burnished with IS grit 60, 80, 100, 120. The coupons were degreased with acetone by swabbing with cotton. The clean and dry specimens were weighed accurately on analytical balance and kept in dessicator until taken out for the study.

The phenolic rod (152 mm long) having two holes each at two ends, one for attaching coupon and the other for attaching drilled pipe plug, was used. Four coupons in each loop were seperately attached with phenolic rod, using an insulating washer to preclude any contact of coupon with screw and nut assembly. For added protection the specimen was attached to the holder using a screw and nut of the same metal composition as the coupon. The holder and coupon assembly were installed in a bypass piping arrangement. The adjusted flow of water was 1.5 ft/sec.

After one month exposure, the specimens were removed and visual observations for scaling and fouling were carried out. The exposed specimens were weighed alongwith the rust

and scale; thereafter the specimens were derusted by mechanical abrasion and weighed again. The exposed specimens were finally pickled with concentrated hydrochloric acid containing 20 g/l Sb_2O_3 and 1 g/l SnCl_2 , washed with water, cleaned with acetone, dried with rosella brand tissue papers and weighed. A weighed blank coupon of the same material was subjected to the identical cleaning procedure used for the test specimens and reweighed to determine blank correction factor to be applied to the coupon weight loss. In the case of pitting, size, shape, number and distribution of the pits were also determined and recorded. "Protected", "Moderate localized", "Moderate Pitting" or "Severe Pitting" were the observed recordings, as the case may be, for the well cleaned and accurately weighed coupons.

The average weight loss of four coupons were taken for calculating the corrosion rate. The study was carried out for twelve months. Average water analysis after month's exposure was recorded and Langelier index was calculated for corrosive and scale forming nature of water.

For scale and corrosion products, the results as expressed are :

(A) Gain or loss during installation g/day

- (B) Loose scale and corrosion products g/day
- (C) Tight scale and Corrosion products g/day
- (D) Actual weight loss of insert g/day
- (E) Total scale and corrosion products g/day

Calculations

$$\text{Corrosion rate (Mpy)} = \frac{W \times 534}{A \times \rho \times T}$$

A = Exposed Surface Area (in²)

ρ = Density of Exposed metal (g/cm³)

T = Time in hour

W = Weight in Milligram

$$\text{Mdd} = \frac{\text{Mpy} \times \rho}{1.437}$$

(Mg/dm²/day)




FIG. 13 NON HEAT TRANSFER LOOP.

CHEMICAL TREATMENT OF COOLING WATER - CAPROLACTAM PLANT

Circulation rate	: 5200 M ³ / hr
Sodium Hexameta Phosphate	: 5 kg/day
or	
E.D.T.A.	: 5 kg/day
Zinc sulphate	: 1 kg / day
Santobrite	: 10 kg/week
Quat-2C	: 1 kg/day
Chlorine	: 4 hrs. in a day
Polyacryloamide	: 1 kg/day
Sulphuric acid	: To maintain pH 7 (40 kg/hr.)

AMMONIA PLANT COOLING WATER

Circulation rate	: 9200 M ³ /hr
Sodium Hexameta Phosphate	: 100 kg/day
Zinc Sulphate	: 20 kg/day
Polyacryloamide	: 10 kg/day
Chlorine	: Continuous
Sulphuric acid	: to maintain pH 7

Table 60

MAKEUP WATER AMMONIA PLANT

Month	Hardness (p.p.m.)	Alkalinity(p.p.m.)	epm(Chloride +
	Chloride (p.p.m.)	Chloride+Sulphate (p.p.m.)	Sulphate) epm (M-Alkalini- -ty)
1	3.45	4.08	0.660
2	3.70	4.12	0.847
3	4.07	3.98	0.814
4	3.10	3.88	0.643
5	4.17	4.38	0.691
6	1.73	5.37	0.540
7	3.25	4.47	0.360
8	3.20	5.71	0.450
9	3.13	3.07	1.150
10	3.72	4.73	0.570
11	4.96	5.03	0.700
12	3.65	3.88	0.700

Table 61

AMMONIA PLANT COOLING TOWER Langelier Index

Month	Makeup	Cooling Water Ammonia Plant
1	+ 0.500	+ 0.200
2	+ 0.700	+ 0.600
3	+ 0.800	+ 0.600
4	+ 0.400	0.0
5	+ 0.600	- 1.00
6	+ 0.650	- 0.500
7	+ 0.900	+ 0.300
8	+ 0.800	+ 1.00
9	+ 0.650	+ 0.200
10	+ 0.850	+ 0.100
11	+ 0.650	- 0.900
12	+ 0.700	0.0

Calculations : Confidence level

AMMONIA PLANT MAKEUP WATER CORROSION RATE IN Mpy

(8.63, 9.42, 9.91, 11.62, 12.02, 12.43)

(5.83, 6.55, 6.78, 7.34, 7.42, 8.12)

 $(9.91 + 11.62) / 2 = 10.77$ median $(6.78 + 7.34) / 2 = 7.06$ median $12.43 - 8.63 = 3.80$ $8.12 - 5.83 = 2.29$ for 99 %

Confidence interval = range x confidence factor

 $= 3.80 \times 0.33 = 1.25$ $= 2.29 \times 0.33 = 0.76$

The corrosion rate is reported as :

$$\begin{array}{l} 10.77 - 1.25 = 9.52 \text{ Mpy} \\ 7.06 - 0.76 = 6.30 \text{ Mpy} \end{array} > \text{Average } 7.91 \text{ mpy}$$

i.e. 7.91 mpy corrosion rate with a confidence level
of 99 % (99 out of 100 coupons will fall in this range)

for 95 % $3.80 \times 0.23 = 0.87$ $2.29 \times 0.23 = 0.53$

The corrosion rate is reported as :

$$\begin{array}{l} 10.77 - 0.87 = 9.90 \\ 7.06 - 0.53 = 6.53 \end{array} > \text{Average } 8.22 \text{ mpy}$$

i.e. 8.22 mpy corrosion rate with a confidence level of 95%
(95 out of 100 coupons will fall within this range).

AMMONIA PLANT (NON HEAT TRANSFER LOOP)

Confidence level of 99 % i.e. 99 samples out of 100 samples will fall in this range.

MAKEUP WATER

Total Hardness as CaCO_3 p.p.m.	: 142
Hardness / Chloride	: 3.02
Total Alkalinity as CaCO_3 p.p.m.	: 195.89
Alkalinity /Chloride + Sulphate	: 4.01
pH	: 8.07

AMMONIA PLANT COOLING WATER

Total Hardness as CaCO_3 p.p.m.	: 229.65
Total Alkalinity as CaCO_3 p.p.m.	: 65.58
pH	: 7.39

99 % CONFIDENCE LEVEL OF CORROSION RATE

Makeup	: 7.91 mpy
Inlet to cooling tower	: 10.59 mpy
Outlet of cooling tower	: 5.42 mpy

Table 62

MAKEUP WATER CAPROLACTAM PLANT

Month	Hardness (p.p.m.)	Alkalinity (p.p.m.)	epm(Chloride+
	Chloride (p.p.m.)	Chloride+Sulphate (p.p.m.)	Sulphate) epm (M-Alkal- inity)
1	2.53	3.65	0.814
2	3.05	3.75	0.710
3	3.51	4.29	0.608
4	3.67	4.64	0.562
5	4.12	4.02	0.773
6	3.58	4.29	0.611
7	4.90	4.85	0.567
8	3.38	5.03	0.550
9	3.23	5.07	0.510
10	3.15	4.24	0.740
11	3.0	3.92	0.690
12	3.72	4.74	0.570

Table 63
CAPROLACTAM PLANT COOLING TOWER
LANGELIER INDEX

Month	Makeup	Cooling water Caprolactam plant
1	+ 0.700	0.0
2	+ 0.700	- 1.700
3	+ 0.600	- 0.700
4	+ 0.800	0.0
5	+ 0.800	- 1.100
6	+ 0.700	+ 0.200
7	+ 0.600	- 0.300
8	+ 0.750	+ 0.190
9	+ 0.750	+ 0.800
10	+ 0.780	+ 0.600
11	+ 0.300	- 0.700
12	+ 0.950	+ 0.270

CAPROLACTAM PLANT NON HEAT TRANSFER LOOP

<u>Makeup</u>	99 % confidence level
Total Hardness as CaCO_3 p.p.m. ..	150.34
Total Alkalinity as CaCO_3 p.p.m. ..	224.04
Hardness / Chloride ..	3.03
Alkalinity / Chloride + Sulphate ..	4.15
pH ..	8.01

CAPROLACTAM PLANT COOLING WATER

Total Hardness as CaCO_3 p.p.m. ..	397.04
Total Alkalinity as CaCO_3 p.p.m. ..	63.75
pH ..	7.13

CORROSION RATE (99% Confidence level)

Makeup ..	8.07 mpy
Inlet to cooling Tower ..	14.01 mpy
Outlet of cooling Tower ..	5.14 mpy

Table 64

AMMONIA PLANT COOLING TOWER

Month	Type of Water	Gain during installation g/day	Loss during installation g/day	Loose Scale and Corrosion products g/day	Tight Scale and Corrosion products g/day	Total Scale & Corrosion products g/day	Actual weight loss g/day
1.	Makeup Inlet	0.00584	-	0.01784	0.00325	0.02109	0.01525
	Outlet	0.00964	-	0.04047	0.01097	0.05144	0.04179
	Outlet	0.00630	-	0.02514	0.00627	0.03141	0.02511
2.	Makeup Inlet	0.00891	-	0.02264	0.00332	0.02596	0.01761
	Outlet	0.01498	-	0.04390	0.00851	0.05349	0.03752
	Outlet	0.01734	-	0.05128	0.00482	0.05610	0.03875
3.	Makeup Inlet	0.00829	-	0.02233	0.00559	0.02793	0.01964
	Outlet	0.01452	-	0.04085	0.00493	0.04579	0.03126
	Outlet	-	0.00764	0.03114	0.00207	0.03315	0.04085
4.	Makeup Inlet	0.00901	-	0.02139	0.00278	0.02418	0.01516
	Outlet	0.00202	-	0.01485	0.00841	0.02326	0.02183
	Outlet	0.00249	-	0.01855	0.00396	0.02252	0.02002
5.	Makeup Inlet	0.00793	-	0.01914	0.00193	0.02107	0.01314
	Outlet	-	0.00114	0.01010	0.00591	0.01600	0.01714
	Outlet	-	0.00153	0.00712	0.00158	0.00870	0.00944
6.	Makeup Inlet	0.01116	-	0.02363	0.00108	0.02470	0.01355
	Outlet	-	0.02561	0.00430	0.00108	0.00538	0.03100
	Outlet	-	0.01603	0.00420	0.00086	0.00506	0.02108
7.	Makeup Inlet	0.01200	-	0.02883	0.00310	0.03194	0.01995
	Outlet	-	0.00024	0.00277	0.00355	0.00633	0.00727
	Outlet	-	0.00055	0.00620	0.00304	0.00924	0.00910
8.	Makeup Inlet	0.00760	-	0.02547	0.00420	0.02968	0.02210
	Outlet	0.00076	-	0.00410	0.00284	0.00690	0.00065
	Outlet	0.00190	-	0.01010	0.00300	0.01320	0.01100

CAPROLACTAM PLANT COOLING TOWER

Month	Type of Water	Gain during installation g/day	Loss during installation g/day	Loose Scale & Corrosion products g/day	Tight Scale & Corrosion products g/day	Total Scale & Corrosion products g/day
1.	Makeup Inlet	0.01186	-	0.02349	0.00089	0.02742
	Outlet	-	0.03624	0.02594	0.00180	0.02775
			0.00792	0.02567	0.00185	0.02752
2.	Makeup Inlet	0.01072	-	0.01963	0.00186	0.02149
	Outlet	0.01528	-	0.02803	0.00178	0.02982
		0.01160	-	0.03076	0.00136	0.03212
3.	Makeup Inlet	0.01638	-	0.03502	0.00143	0.03646
	Outlet	0.00823	-	0.01912	0.00168	0.02081
		0.01658	-	0.03553	0.00198	0.03751
4.	Makeup Inlet	0.01851	-	0.04064	0.00232	0.04296
	Outlet	0.01483	-	0.02831	0.00200	0.03031
		0.01539	-	0.02918	0.00181	0.03099
5.	Makeup Inlet	0.01607	-	0.03430	0.00109	0.03539
	Outlet	-	0.00473	0.00424	0.00177	0.00602
			0.00223	0.00394	0.00096	0.00491
6.	Makeup Inlet	0.01299	-	0.02607	0.00205	0.02812
	Outlet	0.00096	-	0.01363	0.00198	0.01562
		0.00195	-	0.01147	0.00111	0.01258
7.	Makeup Inlet	0.01209	-	0.02802	0.00100	0.02905
	Outlet	-	0.00380	0.00491	0.00095	0.00586
		0.00118	-	0.00640	0.00080	0.00720
8.	Makeup Inlet	0.00900	-	0.02905	0.00109	0.02124
	Outlet	0.00631	-	0.01667	0.00150	0.01818
		0.00431	-	0.01045	0.00110	0.01108

Table 66

AMMONIA PLANT COOLING TOWER

184

Month	Name of the sample	pH	T.D.S p.p.m.	P.Alka linity p.p.m.	M.Alka linity p.p.m.	T.Alka linity p.p.m.	Total Hard ness p.p.m.	Silica p.p.m.	CI' p.p.m.	PO ₄ p.p.m.
1.	Makeup Cooling water	8.1 7.8	375 1252	Nil 5	200 84	200 89	145 326	24 NA	42 112	NA 2.7
2.	Makeup Cooling water	8.2 8.1	315 676	Nil 8	214 134	214 142	148 222	24 NA	40 69	NA 5
3.	Makeup Cooling Water	8.3 8.0	337 820	Nil 6	215 153	215 159	175 309	21 NA	43 87	NA 10
4.	Makeup Cooling Water	8.1 7.7	358 792	Nil 1	225 89	225 90	158 243	16 NA	51 89	NA 4
5.	Makeup Cooling Water	8.0 6.9	292 925	Nil Nil	219 44	219 44	171 280	18 NA	41 137	NA 6
6.	Makeup Cooling Water	7.95 6.7	328 994	Nil 3	290 116	290 119	78 241	21 NA	45 112	NA 5
7.	Makeup Cooling Water	8.10 7.6	372 821	Nil 11	264 217	264 228	169 271	18 NA	52 173	NA 6
8.	Makeup Cooling Water	8.0 8.1	362 890	Nil 36	354 310	354 346	173 288	23 NA	54 170	NA 4
9.	Makeup Cooling Water	8.15 7.7	361 828	Nil Nil	221 121	221 121	172 156	19 NA	55 148	NA 5

Table 67

CAPROLACTAM PLANT COOLING TOWER

Month	Name of the sample	pH	T.D.S p.p.m.	P-Alka linity	M-Alka linity	T-Alka linity	Total Hardness	Silica p.p.m.	CI ¹ p.p.m.	PO ₄ ¹¹ p.p.m.
				p.p.m.	p.p.m.	p.p.m.	p.p.m.	p.p.m.	p.p.m.	p.p.m.
1.	Makeup Cooling Water	8.1 7.6	366 939	Nil 4	252 74	252 78	144 432	20 4	57 185	NA 4
2.	Makeup Cooling Water	8.1 6.7	447 919	4 3	247 34	251 37	177 494	26 7	58 208	NA 4
3.	Makeup Cooling Water	8.1 7.1	327 944	Nil Nil	193 49	193 49	137 401	24 6	39 180	NA 2
4.	Makeup Cooling Water	8.2 7.6	313 847	Nil 5	209 91	209 96	143 366	25 9	39 189	NA 4
5.	Makeup Cooling Water	8.3 6.8	347 848	Nil Nil	213 47	213 47	177 374	25 7	43 172	NA 4
6.	Makeup Cooling Water	8.1 7.6	307 958	Nil 5	223 121	223 126	161 383	16 4	45 190	NA 3.8
7.	Makeup Cooling Water	8.0 7.5	316 872	Nil Nil	228 57	228 57	196 358	22 4	40 70	NA 3
8.	Makeup Cooling Water	8.05 7.79	355 1031	Nil Nil	297 72	297 72	169 415	20 4	50 116	NA 3
9.	Makeup Cooling Water	8.05 7.90	367 1026	Nil 2	309 98	309 100	171 453	21 4	53 113	NA 3